1 15A NCAC 18A .3802 is readopted with changes as published in 35:11 NCR 1149-1153 as follows:

2

15A NCAC 18A .3802 SAMPLE COLLECTION

- 4 (a) Within 30 days after it issues a certificate of completion for a newly constructed private drinking water well, well
- 5 that is newly constructed, [constructed on or after the Effective Date of this Rule,] the local health department shall
- 6 obtain collect water samples and submit them to a certified laboratory for analyses or ensure that water samples are
- 7 <u>collected</u> the water obtained from the well has been sampled by a certified laboratory and tested by a certified
- 8 laboratory, laboratory. All testing shall be done in accordance with the rules of this Section.
- 9 (b) Samples collected from private drinking water wells pursuant to the rules of this Section shall be collected by an
- 10 employee of a local health department, [department] or a certified laboratory. The sample collector shall use aseptic
- sampling techniques for collection of coliform bacteria and sampling techniques and containers for chemical
- 12 constituents following methods described in 40 Code of Federal Regulations CFR 141.23 Inorganic Chemical
- 13 Sampling and Analytical Requirements and 40 Code of Federal Regulations CFR 143.4, 143.4 Monitoring, which are
- 14 <u>hereby</u> incorporated by reference including any subsequent amendments, amendments additions or editions. and
- 15 editions, and available free of charge at: https://www.ecfr.gov/. A copy may be obtained from the National Archives
- and Records Administration through their website at http://www.gpoaccess.gov/cfr/index.html.
- 17 (c) Water samples shall be collected from the sample tap at the well or the closest accessible collection point to the
- 18 water source at with a threadless sample tap, capable of being disinfected, provided the sampling point shall precede
- 19 any water treatment devices.
- 20 (d) It is the responsibility of the The well owner shall to provide access and a source of power for the purpose of
- 21 collecting the required water sample.
- 22 (e) For all new newly constructed private drinking water wells, samples for total coliform and fecal coliform bacteria
- shall be collected after the disinfectant agent has been flushed from the well and water supply system. The water shall
- 24 be determined to be free of disinfectant before collection of samples for bacteria. Required water samples shall not
- be collected from wells that are not constructed and located in accordance with the rules of 15A NCAC 02C .0100
- and .0300, .0300, which are hereby incorporated by reference, including any subsequent amendments and editions.
- 27 (f) Samples shall be transported to the laboratory following the procedures for sample preservation and within holding
- 28 times required in 40 Code of Federal Regulations 141.21(f) Analytical Methodology, CFR 141.23 Inorganic Chemical
- 29 Sampling and Analytical Requirements, and 143.4, and 141.21(f), 143.4 Monitoring, which are is hereby incorporated
- 30 by reference including any subsequent amendments, amendments additions or editions, and editions, and available
- 31 free of charge at: https://www.ecfr.gov./ Copies may be obtained from the National Archives and Records
- 32 Administration through their website at http://www.gpoaccess.gov/cfr/index.html.
- 33 (g) Additional or retest samples may be collected if:
- 34 (1) during the permitting, construction and sampling process, information indicates the potential for
- 35 other contaminants to be present in the groundwater source; or
- 36 (2) if necessary to confirm initial testing results.

37

History Note: Authority G.S. 87-97;
Eff. July 1, 2008. 2008;

3 <u>Readopted Eff. April 1, 2021.</u>