

SUBMISSION FOR PERMANENT RULE

2018 NC Building Code
Table 1004.1.2 (220913 Item B-2)

TABLE 1004.1.2
MAXIMUM FLOOR AREA ALLOWANCES PER OCCUPANT^e

Skating rinks, swimming pools, recreational courts	
Rink, pool, and recreational court	50 gross
Decks	15 gross ^d

For SI: 1 square foot = 0.0929 m², 1 foot = 304.8 mm.

- Floor area in square feet per occupant.
- An assembly occupancy conference room that is accessory to a Group B office occupancy and meeting the requirements of Section 303.1, exception 2, shall be calculated at 100 square feet per occupant for determining the overall occupant load of the associated floor. The assembly occupancy shall be calculated at 15 square feet per occupant for the purpose of determining egress from the room containing the assembly occupancy.
- For mixed uses sum all loads before rounding up to the next whole number.
- Occupant circulation area required by 15A NCAC 18A .2522 around the edge of a swimming pool shall not be included in the deck gross floor area.

(The remainder of Table 1004.1.2 remains unchanged by this proposed amendment.)

....

2018 NC Fire Code
Table 1004.1.2 (220913 Item B-2)

TABLE 1004.1.2
MAXIMUM FLOOR AREA ALLOWANCES PER OCCUPANT^e

Skating rinks, swimming pools, recreational courts	
Rink, pool, and recreational court	50 gross
Decks	15 gross ^d

For SI: 1 square foot = 0.0929 m², 1 foot = 304.8 mm.

- Floor area in square feet per occupant.
- An assembly occupancy conference room that is accessory to a Group B office occupancy and meeting the requirements of Section 303.1, exception 2, shall be calculated at 100 square feet per occupant for determining the overall occupant load of the associated floor. The assembly occupancy shall be calculated at 15 square feet per occupant for the purpose of determining egress from the room containing the assembly occupancy.
- For mixed uses sum all loads before rounding up to the next whole number.
- Occupant circulation area required by 15A NCAC 18A .2522 around the edge of a swimming pool shall not be included in the deck gross floor area.

(The remainder of Table 1004.1.2 remains unchanged by this proposed amendment.)

SUBMISSION FOR PERMANENT RULE

2018 NC Building Code
Table 2902.1 (220913 Item B-1)

**[P] TABLE 2902.1
MINIMUM NUMBER OF REQUIRED PLUMBING FIXTURES**

NO.	CLASSIFICATION	OCCUPANCY	DESCRIPTION	WATER CLOSETS (URINALS: SEE SECTION 419.2 OF THE INTERNATIONAL PLUMBING CODE)		LAVATORIES		BATHTUBS/ SHOWERS	DRINKING FOUNTAIN (SEE SECTION 410 OF THE INTERNATIONAL PLUMBING CODE)	OTHER
				MALE	FEMALE	MALE	FEMALE			
1	Assembly (See Sections 403.2, 403.3 and 403.3.3.2)	A-3	Places of worship and other religious services. <u>Including churches</u> Churches without assembly halls ^c	1 per 150	1 per 75	1 per 200		-	1 per 1,000	1 service sink

e. The number of fixtures provided shall be based on either the capacity of the church sanctuary or the church educational building (including fellowship halls and multiple purpose rooms), whichever is larger and within 300 feet (91.44 m). Remote buildings applying this footnote shall be a maximum of 300 feet (91.44 m) exterior travel distance to the nearest entrance of the building containing required plumbing fixtures ~~plumbing fixtures~~ and the total plumbing fixture access travel distance shall comply with Section 2902.3.2. ~~The path of travel between buildings is not required to be enclosed or covered when applying this footnote.~~

(The remainder of Table 2902.1 remains unchanged by this proposed amendment.)

....

2018 NC Building Code
Section 202 - Definitions (220913 Item B-1)

Travel distance, plumbing fixture access. Travel distance shall be measured from the most remote point of each room, area or space along the natural, unobstructed and accessible path of horizontal and vertical travel to the entrance to the nearest ~~toilet room~~ toilet room containing ~~plumbing fixtures~~ plumbing fixtures required to serve the room, area or space.

....

2018 NC Plumbing Code
Table 403.1 (220913 Item B-1)

TABLE 403.1 - MINIMUM NUMBER OF REQUIRED PLUMBING FIXTURES

NO.	CLASSIFICATION	OCCUPANCY	DESCRIPTION	WATER CLOSETS (URINALS: SEE SECTION 419.2)		LAVATORIES		BATHTUBS/ SHOWERS	DRINKING FOUNTAIN (SEE SECTION 410)	OTHER
				MALE	FEMALE	MALE	FEMALE			

SUBMISSION FOR PERMANENT RULE

1	Assembly (See Sections 403.2, 403.3 and 403.3.3.2)	A-3	Places of worship and other religious services. <u>Including</u> <u>churches</u> Churches without assembly halls ^c	1 per 150	1 per 75	1 per 200	-	1 per 1,000	1 service sink
---	---	-----	---	--------------	----------	-----------	---	-------------	----------------

e. The number of fixtures provided shall be based on either the capacity of the church sanctuary or the church educational building (including fellowship halls and multiple purpose rooms), whichever is larger ~~and within 300 feet (91.44 m)~~. Remote buildings applying this footnote shall be a maximum of 300 feet (91.44 m) exterior travel distance to the nearest entrance of the building containing required plumbing fixtures ~~plumbing fixtures~~ and the total plumbing fixture access travel distance shall comply with Section 403.3.3. The path of travel between buildings is not required to be enclosed or covered when applying this footnote.

(The remainder of Table 403.1 remains unchanged by this proposed amendment.)

....

2018 NC Plumbing Code
Section 202 - Definitions (220913 Item B-1)

Travel distance, plumbing fixture access. Travel distance shall be measured from the most remote point of each room, area or space along the natural, unobstructed and accessible path of horizontal and vertical travel to the entrance to the nearest toilet room ~~toilet room~~ containing plumbing fixtures ~~plumbing fixtures~~ required to serve the room, area or space.