

1 15A NCAC 18A .1511 is readopted as published in 37:23 NCR 2172-2173 as follows:

2

3 **15A NCAC 18A .1511 WATER SUPPLY**

4 (a) Water supplies at local confinement facilities shall meet the requirements in 15A NCAC 18C or 15A NCAC 18A
5 .1700. .1700, as applicable.

6 (b) In local confinement facilities that use a non-community water system, [supply,] as defined at G.S. 130A-313(10),
7 a sample of water shall be collected by the Department of Health and Human Services At least once a year, year and
8 submitted to the North Carolina State Laboratory of Public Health or other laboratory certified by the North Carolina
9 State Laboratory of Public Health under 10A NCAC 42C [41C] .0102 a sample of water shall be collected by the
10 Department and submitted to the Division of Laboratory Services or other laboratory certified by the Department to
11 perform bacteriological examinations.

12 (c) No backflow connections or cross connections with unapproved water supplies shall exist. A local confinement
13 facility's water supply plumbing shall not include cross-connections as set out in 15A NCAC 18C .0102(c)(8).

14 (d) Hot water heating facilities shall be provided. Hot and cold running water under pressure shall be provided to
15 food preparation areas, and any other areas in which water is required for cleaning. Local confinement facilities shall
16 provide water heating facilities, [facilities. Hot] and shall provide hot and cold running water under pressure [shall be
17 provided] to carry out all operations.

18

19 *History Note: Authority G.S. 153A-226;*

20 *Eff. February 1, 1976;*

21 *Readopted Eff. December 5, 1977;*

22 *Amended Eff. September 1, 1990. 1990;*

23 *Readopted Eff. October 1, 2023.*