SUBMISSION FOR PERMANENT RULE

1. Rule-Making Agency: NC Building Code Council	
2. Rule citation & name (name not required for repeal): 2024 North Carolina Existing Building Code Section 803.2.1.2 Low-rise buildings (230314 Item B-12)	
3. Action:	READOPTION REPEAL through READOPTION
4. Rule exempt from RRC review?	 5. Rule automatically subject to legislative review? Yes. Cite authority: No.
Image: No 6. Notice for Proposed Rule:	No No
 Notice Required Notice of Text published on: May 15, 2023 Link to Agency notice: https://www.ncosfm.gov/codes/building-code-council-bcc/bcc-hearing-notices Hearing on: June 13, 2023 Adoption by Agency on: September 12, 2023 Notice not required under G.S.: Adoption by Agency on: 	
7. Rule establishes or increases a fee? (See G.S. 12-3.1)	8. Fiscal impact. Check all that apply.
 Yes Agency submitted request for consultation on: Consultation not required. Cite authority: No 	 □ This Rule was part of a combined analysis. □ State funds affected □ Local funds affected □ Substantial economic impact (≥\$1,000,000) □ Approved by OSBM ○ No fiscal note required
9. REASON FOR ACTION	
9A. What prompted this action? Check all that apply: Agency Legislation enacted by the General Assembly Court order / cite: Cite Session Law: Federal statute / cite: Petition for rule-making Federal regulation / cite: Other: 9B. Explain: The purpose of this amendment is to clarify that an alteration level 2 can be performed without requiring an automatic sprinkler system for Group R-3 occupancy classifications when the building contains a maximum of two dwelling units in a low rise building and is not otherwise required to be sprinklered. This is consistent with the sprinkler requirements for a change use as addressed in NCEBC Section 1011.2.1.2 and Table 1011.2.1 for Group R-3 as well as Section 904.	
10. Rulemaking Coordinator: David Bruce Rittlinger David B. Rittlinger Phone: (919)647-0008 E-Mail: david.rittlinger@ncdoi.gov	11. Signature of Agency Head* or Rule-making Coordinator:
Additional agency contact, if any: Phone: E-Mail:	*If this function has been delegated (reassigned) pursuant to G.S. 143B-10(a), submit a copy of the delegation with this form. Typed Name: David Bruce Rittlinger Title: (Interim) Deputy commissioner of Engineering & Chief Code Consultant
RRC AND OAH USE ONLY	
Action taken: RRC extended period of review: RRC determined substantial changes: Withdrawn by agency Subject to Legislative Review Other:	

SUBMISSION FOR PERMANENT RULE

803.2.1.2 Low-rise buildings. Work areas that increase the fire area or calculated occupant load above the limits listed in Section 903.2 of the *International Building Code* shall meet the requirements of those sections.

Exception: Where an automatic sprinklers system is not existing in a *building* or otherwise required by Section 803, *North Carolina Building Code* Section 903.2.8 shall not be applied for Group R-3.