


SUBMISSION FOR PERMANENT RULE

1. Rule-Making Agency: NC Building Code Council	
2. Rule citation & name (name not required for repeal): 2024 NC Mechanical Code Sections 1101, 1103, 1104, 1106, 1107, 1109, 1110 and Chapter 15 (231212 Item B-5)	
3. Action: <input type="checkbox"/> ADOPTION <input checked="" type="checkbox"/> AMENDMENT <input type="checkbox"/> REPEAL <input type="checkbox"/> READOPTION <input type="checkbox"/> REPEAL through READOPTION	
4. Rule exempt from RRC review? <input type="checkbox"/> Yes. Cite authority: <input checked="" type="checkbox"/> No	5. Rule automatically subject to legislative review? <input type="checkbox"/> Yes. Cite authority: <input checked="" type="checkbox"/> No
6. Notice for Proposed Rule: <input checked="" type="checkbox"/> Notice Required Notice of Text published on: January 16, 2024 in NC Register Link to Agency notice: https://www.ncosfm.gov/codes/building-code-council-bcc/bcc-hearing-notice Hearing on: March 18, 2024 Adoption by Agency on: March 19, 2024 <input type="checkbox"/> Notice not required under G.S.: Adoption by Agency on:	
7. Rule establishes or increases a fee? (See G.S. 12-3.1) <input type="checkbox"/> Yes Agency submitted request for consultation on: Consultation not required. Cite authority: <input checked="" type="checkbox"/> No	8. Fiscal impact. Check all that apply. <input type="checkbox"/> This Rule was part of a combined analysis. <input type="checkbox"/> State funds affected <input type="checkbox"/> Local funds affected <input type="checkbox"/> Substantial economic impact (\geq \$1,000,000) <input type="checkbox"/> Approved by OSBM <input checked="" type="checkbox"/> No fiscal note required
9. REASON FOR ACTION	
9A. What prompted this action? Check all that apply: <input checked="" type="checkbox"/> Agency <input type="checkbox"/> Court order / cite: <input type="checkbox"/> Federal statute / cite: <input type="checkbox"/> Federal regulation / cite: <input type="checkbox"/> Legislation enacted by the General Assembly Cite Session Law: <input type="checkbox"/> Petition for rule-making <input type="checkbox"/> Other:	
9B. Explain: These changes will update the 2024 NCMC to reference the latest refrigerant standards and listings, and align Chapter 11 with those updated references. These changes include updating refrigerant classifications, allowed amounts per occupied space, required listings, and installation and testing requirements. The changes are expected to help smooth the transition to alternative refrigerants as HFC refrigerant production is phased-down. The delayed effective date of this Rule is January 1, 2025. The Statutory authority for Rule-making is G. S. 143-136; 143-138.	
10. Rulemaking Coordinator: David B. Rittlinger David B. Rittlinger Phone: (919)647-0008 E-Mail: david.rittlinger@ncdoi.gov Additional agency contact, if any: Phone: E-Mail:	11. Signature of Agency Head* or Rule-making Coordinator:  <hr/> *If this function has been delegated (reassigned) pursuant to G.S. 143B-10(a), submit a copy of the delegation with this form. Typed Name: David B. Rittlinger Title: Chief Code Consultant
RRC AND OAH USE ONLY	
Action taken: <input type="checkbox"/> RRC extended period of review: <input type="checkbox"/> RRC determined substantial changes: <input type="checkbox"/> Withdrawn by agency <input type="checkbox"/> Subject to Legislative Review <input type="checkbox"/> Other:	

SUBMISSION FOR PERMANENT RULE

1101.2.1 Group A2L, A2, A3 and B1 high-probability equipment. High-probability equipment using Group A2L, A2, A3, or B1 refrigerant shall comply with UL 484, UL/CSA 60335-2-40, or UL/CSA 60335-2-89.

....

**TABLE 1103.1
REFRIGERANT CLASSIFICATION, AMOUNT AND OEL**

CHEMICAL REFRIGERANT	FORMULA	CHEMICAL NAME OF BLEND	REFRIGERANT SAFETY GROUP CLASSIFICATION	AMOUNT OF REFRIGERANT PER OCCUPIED SPACE						[F] DEGREES OF HAZARD ^a	
				RCL			LFL		OEL ^d		
				Pounds per 1,000 cubic feet lb/Mcf	ppm	g/m ³	lb/Mcf	ppm	g/m ³		OEL ^e ppm
R-11 ^{d,e}	CCl ₃ F	trichlorofluoromethane	A1	0.39	1,100	6.2 6.1				1,000	2-0-0 ^b
R-12 ^{d,e}	CCl ₂ F ₂	dichlorodifluoromethane	A1	5.6	18,000	90				1,000	2-0-0 ^b
R-13 ^{d,e}	CClF ₃	chlorotrifluoromethane	A1	—	—	—				1,000	2-0-0 ^b
R-13B1 ^{d,e}	CBrF ₃	bromotrifluoromethane	A1	—	—	—				1,000	2-0-0 ^b
<u>R-1311</u>	<u>CF₃I</u>	<u>trifluoroiodomethane</u>	<u>A1</u>	<u>1.0</u>	<u>2,000</u>	<u>16</u>				<u>500</u>	
R-14	CF ₄	tetrafluoromethane (carbon tetrafluoride)	A1	25	110,000	400				1,000	2-0-0 ^b
R-22	CHClF ₂	chlorodifluoromethane	A1	13	59,000	210				1,000	2-0-0 ^b
R-23	CHF ₃	trifluoromethane (fluoroform)	A1	7.3	41,000	120				1,000	2-0-0 ^b
R-30	CH ₂ Cl ₂	dichloromethane (methylene chloride)	B1	—	—	—				—	—
<u>R-31</u>	<u>CH₂ClF</u>	<u>Chlorofluoromethane</u>	<u>-</u>	<u>—</u>	<u>—</u>	<u>—</u>				<u>—</u>	<u>—</u>
R-32	CH ₂ F ₂	difluoromethane (methylene fluoride)	A2 <u>A2L</u>	4.8	36,000	77	<u>19.1</u>	<u>144.00</u> <u>0</u>	<u>306</u>	1,000	1-4-0
R-40	CH ₃ Cl	chloromethane (methyl chloride)	B2	—	—	—				—	—
<u>R-41</u>	<u>CH₃F</u>	<u>Fluoromethane (methyl fluoride)</u>	<u>-</u>	<u>—</u>	<u>—</u>	<u>—</u>				<u>—</u>	
R-50	CH ₄	methane	A3	—	—	—		<u>50,000</u>		1,000	—
R-113 ^{d,e}	CCl ₂ FCClF ₂	1,1,2-trichloro-1,2,2-trifluoroethane	A1	1.2	2,600	20				1,000	2-0-0 ^b
R-114 ^{d,e}	CClF ₂ CClF ₂	1,2-dichloro-1,1,2,2-tetrafluoroethane	A1	8.7	20,000	140				1,000	2-0-0 ^b
R-115	CClF ₂ CF ₃	chloropentafluoroethane	A1	47	120,000	760				1,000	—
R-116	CF ₃ CF ₃	hexafluoroethane	A1	34	97,000	550				1,000	1-0-0
R-123	CHCl ₂ CF ₃	2,2-dichloro-1,1,1-trifluoroethane	B1	3.5	9,100	57				50	2-0-0 ^b
R-124	CHClFCF ₃	2-chloro-1,1,1,2-tetrafluoroethane	A1	3.5	10,000	56				1,000	2-0-0 ^b
R-125	CHF ₂ CF ₃	pentafluoroethane	A1	23	75,000	370				1,000	2-0-0 ^b
R-134a	CH ₂ FCF ₃	1,1,1,2-tetrafluoroethane	A1	13	50,000	210				1,000	2-0-0 ^b
R-141b	CH ₃ CCl ₂ F	1,1-dichloro-1-fluoroethane	—	0.78	2,600	12	<u>17.8</u>	<u>60,000</u>	<u>287</u>	500	2-1-0

SUBMISSION FOR PERMANENT RULE

R-142b	CH ₃ CClF ₂	1-chloro-1,1-difluoroethane	A2	5.1	20,000	83 <u>82</u>	<u>20.4</u>	<u>80,000</u>	<u>329</u>	1,000	2-4-0
R-143a	CH ₃ CF ₃	1,1,1-trifluoroethane	A2 <u>A2L</u>	4.5 <u>4.4</u>	21,000	70	<u>17.5</u>	<u>82,000</u>	<u>282</u>	1,000	2-0-0 ^b
R-152a	CH ₃ CHF ₂	1,1-difluoroethane	A2	2.0	12,000	32	<u>8.1</u>	<u>48,000</u>	<u>130</u>	1,000	1-4-0
R-170	CH ₃ CH ₃	ethane	A3	0.54	7,000	8.7 <u>8.6</u>	<u>2.4</u>	<u>31,000</u>	<u>38</u>	1,000	2-4-0
R-E170	CH ₃ OCH ₃	Methoxymethane (dimethyl ether)	A3	1.0	8,500	16	<u>4.0</u>	<u>34,000</u>	<u>64</u>	1,000	—
R-218	CF ₃ CF ₂ CF ₃	octafluoropropane	A1	43	90,000	690				1,000	2-0-0 ^b
R-227ea	CF ₃ CHF ₂ CF ₃	1,1,1,2,3,3,3-heptafluoropropane	A1	36	84,000	580				1,000	—
R-236fa	CF ₃ CH ₂ CF ₃	1,1,1,3,3,3-hexafluoropropane	A1	21	55,000	340				1,000	2-0-0 ^b
R-245fa	CHF ₂ CH ₂ CF ₃	1,1,1,3,3-pentafluoropropane	B1	12	34,000	190				300	2-0-0 ^b
R-290	CH ₃ CH ₂ CH ₃	propane	A3	0.56 <u>0.59</u>	5,300	9.5	<u>2.4</u>	<u>21,000</u>	<u>38</u>	1,000	2-4-0
R-C318	-(CF ₂) ₄ -	octafluorocyclobutane	A1	41	80,000	660 <u>650</u>				1,000	—

(continued)

TABLE 1103.1—continued
REFRIGERANT CLASSIFICATION, AMOUNT AND OEL

CHEMICAL REFRIGERANT	FORMULA	CHEMICAL NAME OF BLEND	REFRIGERANT SAFETY GROUP CLASSIFICATION	AMOUNT OF REFRIGERANT PER OCCUPIED SPACE						[F] DEGREES OF HAZARD ^a	
				RCL			LFL				OEL ^d
				Pounds per 1,000 cubic feet lb/Mcf	ppm	g/m ³	lb/Mcf	ppm	g/m ³		OEL ^a ppm
R-400 ^{d,e}	zeotrope	R-12/114 (50.0/50.0)	A1	10	28,000	160				1,000	2-0-0 ^b
R-400 ^{d,e}	zeotrope	R-12/114 (60.0/40.0)	A1	11	30,000	170				1,000	—
R-401A	zeotrope	R-22/152a/124 (53.0/13.0/34.0)	A1	6.6	27,000	110				1,000	2-0-0 ^b
R-401B	zeotrope	R-22/152a/124 (61.0/11.0/28.0)	A1	7.2	30,000	120				1,000	2-0-0 ^b
R-401C	zeotrope	R-22/152a/124 (33.0/15.0/52.0)	A1	5.2	20,000	84				1,000	2-0-0 ^b
R-402A	zeotrope	R-125/290/22 (60.0/2.0/38.0)	A1	17	66,000	270				1,000	2-0-0 ^b
R-402B	zeotrope	R-125/290/22 (38.0/2.0/60.0)	A1	15	63,000	240				1,000	2-0-0 ^b
R-403A	zeotrope	R-290/22/218 (5.0/75.0/20.0)	A2	7.6	33,000	120				1,000	2-0-0 ^b
R-403B	zeotrope	R-290/22/218 (5.0/56.0/39.0)	A1	18	70,000 <u>68,000</u>	290				1,000	2-0-0 ^b
R-404A	zeotrope	R-125/143a/134a (44.0/52.0/4.0)	A1	31	130,000	500				1,000	2-0-0 ^b
R-405A	zeotrope	R-22/152a/142b/C318 (45.0/7.0/5.5/42.5)	—	16	57,000	260				1,000	—
R-406A	zeotrope	R-22/600a/142b (55.0/4.0/41.0)	A2	4.7	21,000	25 <u>75</u>	<u>18.8</u>	<u>82,000</u>	<u>301.9</u>	1,000	—

SUBMISSION FOR PERMANENT RULE

R-407A	zeotrope	R-32/125/134a (20.0/40.0/40.0)	A1	19	83,000	300				1,000	2-0-0 ^b
R-407B	zeotrope	R-32/125/134a (10.0/70.0/20.0)	A1	21	79,000	330				1,000	2-0-0 ^b
R-407C	zeotrope	R-32/125/134a (23.0/25.0/52.0)	A1	18	81,000	290				1,000	2-0-0 ^b
R-407D	zeotrope	R-32/125/134a (15.0/15.0/70.0)	A1	16	68,000	250				1,000	2-0-0 ^b
R-407E	zeotrope	R-32/125/134a (25.0/15.0/60.0)	A1	17	80,000	280				1,000	2-0-0 ^b
R-407F	zeotrope	R-32/125/134a (30.0/30.0/40.0)	A1	20	95,000	320				1,000	—
R-407G	zeotrope	R-32/125/134a (2.5/2.5/95.0)	A1	13	52,000	210				1,000	—
R-407H	zeotrope	R-32/125/134a (32.5/15.0/52.5)	A1	19	92,000	300				1,000	—
<u>R-407I</u>	<u>zeotrope</u>	<u>R-32/125/134a (19.5/8.5/72.0)</u>	<u>A1</u>	<u>16</u>	<u>71,100</u>	<u>250</u>				<u>1,000</u>	
R-408A	zeotrope	R-125/143a/22 (7.0/46.0/47.0)	A1	21	95,000 94,000	340 330				1,000	2-0-0 ^b
R-409A	zeotrope	R-22/124/142b (60.0/25.0/15.0)	A1	7.1	29,000	110				1,000	2-0-0 ^b
R-409B	zeotrope	R-22/124/142b (65.0/25.0/10.0)	A1	7.3	30,000	120				1,000	2-0-0 ^b
R-410A	zeotrope	R-32/125 (50.0/50.0)	A1	26	140,000	420				1,000	2-0-0 ^b
R-410B	zeotrope	R-32/125 (45.0/55.0)	A1	27	140,000	430				1,000	2-0-0 ^b
R-411A	zeotrope	R-127/22/152a (1.5/87.5/11.0)	A2	2.9	14,000	46	<u>11.6</u>	<u>55,000</u>	<u>185.6</u>	990 <u>970</u>	—
R-411B	zeotrope	R-1270/22/152a (3.0/94.0/3.0)	A2	2.8	13,000	45	<u>14.8</u>	<u>70,000</u>	<u>238.3</u>	980 <u>940</u>	—
R-412A	zeotrope	R-22/218/142b (70.0/5.0/25.0)	A2	5.1	22,000	82	<u>20.5</u>	<u>87,000</u>	<u>328.6</u>	1,000	—
R-413A	zeotrope	R-218/134a/600a (9.0/88.0/3.0)	A2	5.8	22,000	94 <u>93</u>	<u>23.4</u>	<u>88,000</u>	<u>374.9</u>	1,000	—
R-414A	zeotrope	R-22/124/600a/142b (51.0/28.5/4.0/16.5)	A1	6.4	26,000	100				1,000	—
R-414B	zeotrope	R-22/124/600a/142b (50.0/39.0/1.5/9.5)	A1	6.0	23,000	95 <u>96</u>				1,000	—

(continued)

TABLE 1103.1—continued
REFRIGERANT CLASSIFICATION, AMOUNT AND OEL

CHEMICAL REFRIGERANT	FORMULA	CHEMICAL NAME OF BLEND	REFRIGERANT SAFETY GROUP CLASSIFICATION	AMOUNT OF REFRIGERANT PER OCCUPIED SPACE							[F] DEGREES OF HAZARD ^a
				RCL			LFL			OEL ^d	
				Pounds per 1,000 cubic feet lb/Mcf	ppm	g/m ³	lb/Mcf	ppm	g/m ³	OEL ^e ppm	
R-415A	zeotrope	R-22/152a (82.0/18.0)	A2	2.9	14,000	47	<u>11.7</u>	<u>56,000</u>	<u>187.9</u>	1,000	—
R-415B	zeotrope	R-22/152a (25.0/75.0)	A2	2.1	12,000	34	<u>8.4</u>	<u>47,000</u>	<u>135.1</u>	1,000	—
R-416A	zeotrope	R-134a/124/600 (59.0/39.5/1.5)	A1	3.9	14,000	62				1,000	2-0-0 ^b
R-417A	zeotrope	R-125/134a/600 (46.6/50.0/3.4)	A1	3.5	13,000	56 <u>55</u>				1,000	2-0-0 ^b

SUBMISSION FOR PERMANENT RULE

R-417B	zeotrope	R-125/134a/600 (79.0/18.3/2.7)	A1	4.3	15,000	70 69				1,000	—
R-417C	zeotrope	R-125/134a/600 (19.5/78.8/1.7)	A1	5.4	21,000	87				1,000	—
R-418A	zeotrope	R-290/22/152a (1.5/96.0/2.5)	A2	4.8	22,000	77	<u>19.2</u>	<u>89,000</u>	<u>308.4</u>	1,000	—
R-419A	zeotrope	R-125/134a/E170 (77.0/19.0/4.0)	A2	4.2	15,000	67	<u>16.7</u>	<u>60,000</u>	<u>268.6</u>	1,000	—
R-419B	zeotrope	R-125/134a/E170 (48.5/48.0/3.5)	A2	4.6	17,000	74	<u>18.5</u>	<u>69,000</u>	<u>297.3</u>	1,000	—
R-420A	zeotrope	R-134a/142b (88.0/12.0)	A1	12	45,000 44,000	190 180				1,000	2-0-0 ^b
R-421A	zeotrope	R-125/134a (58.0/42.0)	A1	17	61,000	280				1,000	2-0-0 ^b
R-421B	zeotrope	R-125/134a (85.0/15.0)	A1	21	69,000	330				1,000	2-0-0 ^b
R-422A	zeotrope	R-125/134a/600a (85.1/11.5/3.4)	A1	18	63,000	290				1,000	2-0-0 ^b
R-422B	zeotrope	R-125/134a/600a (55.0/42.0/3.0)	A1	16	56,000	250				1,000	2-0-0 ^b
R-422C	zeotrope	R-125/134a/600a (82.0/15.0/3.0)	A1	18	62,000	290				1,000	2-0-0 ^b
R-422D	zeotrope	R-125/134a/600a (65.1/31.5/3.4)	A1	16	58,000	260				1,000	2-0-0 ^b
R-422E	zeotrope	R-125/134a/600a (58.0/39.3/2.7)	A1	16	57,000	260				1,000	—
R-423A	zeotrope	R-134a/227ea (52.5/47.5)	A1	19	59,000	310 300				1,000	2-0-0 ^b
R-424A	zeotrope	R-125/134a/600a/600/601a (50.5/47.0/0.9/1.0/0.6)	A1	6.2	23,000	100				970 990	2-0-0 ^b
R-425A	zeotrope zeotrope	R-32/134a/227ea (18.5/69.5/12.0)	A1	16	72,000	260				1,000	2-0-0 ^b
R-426A	zeotrope	R-125/134a/600a/601a (5.1/93.0/1.3/0.6)	A1	5.2	20,000	83				990	—
R-427A	zeotrope	R-32/125/143a/134a (15.0/25.0/10.0/50.0)	A1	18	79,000	290				1,000	2-1-0
R-428A	zeotrope	R-125/143a/290/600a (77.5/20.0/0.6/1.9)	A1	23	83,000 84,000	370				1,000	—
R-429A	zeotrope	R-E170/152a/600a (60.0/10.0/30.0)	A3	0.81	6,300	13	<u>3.2</u>	<u>25,000</u>	<u>83.8</u>	1,000	—
R-430A	zeotrope	R-152a/600a (76.0/24.0)	A3	1.3	8,000	21	<u>5.2</u>	<u>32,000</u>	<u>44.0</u>	1,000	—
R-431A	zeotrope	R-290/152a (71.0/29.0)	A3	0.69 0.68	5,500	11	<u>2.7</u>	<u>22,000</u>	<u>38.6</u>	1,000	—
R-432A	zeotrope	R-1270/E170 (80.0/20.0)	A3	0.13	1,200	2.1	<u>2.4</u>	<u>22,000</u>	<u>39.2</u>	700 550	—
R-433A	zeotrope	R-1270/290 (30.0/70.0)	A3	0.34	3,100	5.5	<u>2.4</u>	<u>20,000</u>	<u>32.4</u>	880 760	—
R-433B	zeotrope	R-1270/290 (5.0-95.0)	A3	0.51 0.39	4,500 3,500	8.1 6.3	<u>2.0</u>	<u>18,000</u>	<u>32.1</u>	950	—
R-433C	zeotrope	R-1270/290 (25.0-75.0)	A3	0.41	3,600 3,700	6.6 6.5	<u>2.0</u>	<u>18,000</u>	<u>83.8</u>	790	—
R-434A	zeotrope	R-125/143a/600a (63.2/18.0/16.0/2.8)	A1	20	73,000	320				1,000	—

(continued)

TABLE 1103.1—continued
REFRIGERANT CLASSIFICATION, AMOUNT AND OEL

SUBMISSION FOR PERMANENT RULE

CHEMICAL REFRIGERANT	FORMULA	CHEMICAL NAME OF BLEND	REFRIGERANT SAFETY GROUP CLASSIFICATION	AMOUNT OF REFRIGERANT PER OCCUPIED SPACE							[F] DEGREE S OF HAZARD ^a
				RCL			LFL			OEL ^d	
				Pounds per 1,000 cubic feet lb/Mcf	ppm	g/m ³	lb/Mcf	ppm	g/m ³	OEL ^e ppm	
R-435A	zeotrope	R-E170/152a (80.0/20.0)	A3	1.1	8,500	17	4.3	34,000	68.2	1,000	—
R-436A	zeotrope	R-290/600a (56.0/44.0)	A3	0.50	4,000	8.1	2.0	16,000	32.3	1,000	—
R-436B	zeotrope	R-290/600a (52.0/48.0)	A3	0.51	4,000	8.1 8.2	2.0	16,000	32.7	1,000	—
<u>R-436C</u>	<u>zeotrope</u>	<u>R-290/600a (95.0/5.0)</u>	<u>A3</u>	<u>0.57</u>	<u>5,000</u>	<u>9.1</u>	<u>2.3</u>	<u>20,000</u>	<u>36.5</u>	<u>1,000</u>	
R-437A	zeotrope	R-125/134a/600/601 (19.5/78.5/1.4/0.6)	A1	5.0 5.1	19,000	82				990	—
R-438A	zeotrope	R-32/125/134a/600/601a (8.5/45.0/44.2/1.7/0.6)	A1	4.9	20,000	79				990	—
R-439A	zeotrope	R-32/125/600a (50.0/47.0/3.0)	A2	4.7	26,000	76	18.9	104,000	303.3	990 1,000	—
R-440A	zeotrope	R-290/134a/152a (0.6/1.6/97.8)	A2	1.9	12,000	31	7.8	46,000	124.7	1,000	—
R-441A	zeotrope	R-170/290/600a/600 (3.1/54.8/6.0/36.1)	A3	0.39	3,200	6.3	2.0	16,000	31.7	1,000	—
R-442A	zeotrope	R-32/125/134a/152a/227ea (31.0/31.0/30.0/3.0/5.0)	A1	21	100,000	330				1,000	—
R-443A	zeotrope	R-1270/290/600a (55.0/40.0/5.0)	A3	0.19	1,700	3.1	2.2	20,000	35.6	580 640	—
R-444A	zeotrope	R-32/152a/1234ze(E) (12.0/5.0/83.0)	A2 ^e A2L	5.1	21,000	81	19.9	82,000	324.8	850	—
R-444B	zeotrope	R-32/152a/1234ze(E) (41.5/10.0/48.5)	A2 ^e A2L	4.3	23,000	69	17.3	93,000	277.3	890 930	—
R-445A	zeotrope	R-744/134a/1234ze(E) (6.0/9.0/85.0)	A2 ^e A2L	4.2	16,000	67	2.7	63,000	347.4	930	—
R-446A	zeotrope	R-32/1234ze(E)/600 (68.0/29.0/3.0)	A2 ^e A2L	2.5	16,000	39	13.5	62,000	217.4	960	—
R-447A	zeotrope	R-32/125/1234ze(E) (68.0/3.5/28.5)	A2 ^e A2L	2.6	16,000	42	18.9	65,000	303.5	900 960	—
R-447B	zeotrope	R-32/125/1234ze(E) (68.0/8.0/24.0)	A2 ^e A2L	2.3 2.6	30,000 16,000	36 42	20.6	121,000	312.7	970	—
R-448A	zeotrope	R-32/125/1234yf/134a/1234ze(E) (26.0/26.0/20.0/21.0/7.0)	A1	24	110,000	390				890 860	—
R-449A	zeotrope	R-32/125/1234yf/134a (24.3/24.7/25.3/25.7)	A1	23	100,000	370				830 840	—
R-449B	zeotrope	R-32/125/1234yf/134a (25.2/24.3/23.2/27.3)	A1	23	100,000	370				850	—
R-449C	zeotrope	R-32/125/1234yf/134a (20.0/20.0/31.0/29.0)	A1	23	98,000	360				800	—

SUBMISSION FOR PERMANENT RULE

R-450A	zeotrope	R-134a/1234ze(E) (42.0/58.0)	A1	20	72,000	32 0				880	—
R-451A	zeotrope	R-1234yf/134a (89.8/10.2)	A2^s <u>A2L</u>	5.3 <u>5.0</u>	18,000	81	<u>20.3</u>	<u>70,000</u>	<u>326.6</u>	520 <u>530</u>	—
R-451B	zeotrope	R-1234yf/134a (88.8/11.2)	A2^s <u>A2L</u>	5.3 <u>5.0</u>	18,000	81	<u>20.3</u>	<u>70,000</u>	<u>326.6</u>	530	—
R-452A	zeotrope	R-32/125/1234yf (11.0/59.0/30.0)	A1	27	10,000 <u>100,000</u> 0	44 0				780 <u>790</u>	—
R-452B	zeotrope	R-32/125/1234yf (67.0/7.0/26.0)	A2^s <u>A2L</u>	23 <u>4.8</u>	30,000	36 0 <u>77</u>	<u>19.3</u>	<u>119,000</u> 0	<u>310.5</u>	870	—
R-452C	zeotrope	R-32/125/1234yf (12.5/61.0/26.5)	A1	27	100,000	43 0				800 <u>810</u>	—
R-453A	zeotrope	R-32/125/134a/227ea/600/601a (20.0/20.0/53.8/5.0/0.6/ 0.6)	A1	7.8	34,000	12 0				1,000	—
R-454A	zeotrope	R-32/1234yf (35.0/65.0)	A2^s <u>A2L</u>	28 <u>3.2</u>	16,000	45 0 <u>52</u>	<u>18.3</u>	<u>63,000</u>	<u>293.9</u>	690	—
R-454B	zeotrope	R-32/1234yf (68.9/31.1)	A2^s <u>A2L</u>	22 <u>3.1</u>	19,000	36 0 <u>49</u>	<u>22.0</u>	<u>77,000</u>	<u>352.6</u>	850	—

(continued)

TABLE 1103.1—continued
REFRIGERANT CLASSIFICATION, AMOUNT AND OEL

CHEMICAL REFRIGERANT	FORMULA	CHEMICAL NAME OF BLEND	REFRIGERANT SAFETY GROUP CLASSIFICATION	AMOUNT OF REFRIGERANT PER OCCUPIED SPACE						[F] DEGREE S OF HAZARD ^a	
				RCL			LFL		OEL ^d		
				Pounds per 1,000 cubic feet lb/ Mcf	ppm	g/ m ³	lb/ Mcf	ppm	g/m ³		OEL ^e ppm
R-454C	zeotrope	R-32/1234yf (21.5/78.5)	A2^s <u>A2L</u>	29 <u>4.4</u>	19,000	46 0 <u>71</u>	<u>18.0</u>	<u>62,000</u>	<u>289.5</u>	620	—
R-455A	zeotrope	R-744/32/1234yf (3.0/21.5/75.5)	A2^s <u>A2L</u>	23 <u>4.9</u>	30,000 <u>22,000</u>	38 0 <u>79</u>	<u>26.9</u>	<u>118,000</u> 0	<u>432.1</u>	650	—
R-456A	zeotrope	R-32/134a/1234ze(E) (6.0/45.0/49.0)	A1	20	77,000	32 0				900	—
R-457A	zeotrope	R-32/1234yf/152a (18.0/70.0/12.0)	A2^s <u>A2L</u>	25 <u>3.4</u>	15,000	40 0 <u>54</u>	<u>13.5</u>	<u>60,000</u>	<u>216.3</u>	650	—
<u>R-457B</u>	<u>zeotrope</u>	<u>R-32/1234yf/152a</u> <u>(35.0/55.0/10.0)</u>	<u>A2L</u>	<u>3.7</u>	<u>19,000</u>	<u>59</u>	<u>14.9</u>	<u>76,000</u>	<u>239</u>	<u>730</u>	
R-458A	zeotrope	R-32/125/134a/227ea/236fa (20.5/4.0/61.4/13.5/0.6)	A1	18	76,000	28 0				1,000	—
R-459A	zeotrope	R-32/1234yf/1234ze(E) (68.0/26.0/6.0)	A2^s <u>A2L</u>	23 <u>4.3</u>	27,000	36 0 <u>69</u>	<u>17.4</u>	<u>107,000</u> 0	<u>278.7</u>	870	—

SUBMISSION FOR PERMANENT RULE

R-459B	zeotrope	R-32/1234yf/1234ze(E) (21.0/69.0/10.0)	A2 <u>A2L</u>	30	16,000 <u>25,000</u>	47 <u>0</u> <u>92</u>	<u>23.3</u>	<u>99,000</u>	<u>373.5</u>	640	—
R-460A	zeotrope	R-32/125/134a/1234ze(E) (12.0/52.0/14.0/22.0)	A1	24	92,000	38 0				650 <u>950</u>	—
R-460B	zeotrope	R-32/125/134a/1234ze(E) (28.0/25.0/20.0/27.0)	A1	25	120,000	40 0				950	—
<u>R-460C</u>	<u>zeotrope</u>	<u>R-32/125/134a/1234ze(E)</u> <u>(2.5/2.5/46.0/49.0)</u>	<u>A1</u>	<u>20</u>	<u>73,000</u>	<u>31</u> <u>0</u>				<u>900</u>	
R-461A	zeotrope	R-125/143a/134a/227ea/600a (55.0/5.0/32.0/5.0/3.0)	A1	17	61,000	27 0				1,000	—
R-462A	zeotrope	R-32/125/143a/134a/600 (9.0/42.0/2.0/44.0/3.0)	A2	3.9	16,000	62	<u>16.6</u>	<u>105,000</u> <u>0</u>	<u>265.8</u>	1,000	—
R-463A	zeotrope	R-744/32/125/1234yf/134a (6.0/36.0/30.0/14.0/14.0)	A1	19	98,000	30 0				990	—
<u>R-464A</u>	<u>zeotrope</u>	<u>R-32/125/1234ze(E)/227ea</u> <u>(27.0/27.0/40.0/6.0)</u>	<u>A1</u>	<u>27</u>	<u>120,000</u> <u>0</u>	<u>43</u> <u>0</u>				<u>930</u>	
<u>R-465A</u>	<u>zeotrope</u>	<u>R-32/290/1234yf</u> <u>(21.0/7.9/71.1)</u>	<u>A2</u>	<u>2.5</u>	<u>12,000</u>	<u>40</u>	<u>10.0</u>	<u>98,000</u>	<u>160.9</u>	<u>660</u>	
<u>R-466A</u>	<u>zeotrope</u>	<u>R-32/125/1311 (49.0/11.5/39.5)</u>	<u>A1</u>	<u>6.2</u>	<u>30,000</u>	<u>99</u>				<u>860</u>	
<u>R-467A</u>	<u>zeotrope</u>	<u>R-32/125/134a/600a</u> <u>(22.0/5.0/72.4/0.6)</u>	<u>A2L</u>	<u>6.7</u>	<u>31,000</u>	<u>11</u> <u>0</u>				<u>1,000</u>	
<u>R-468A</u>	<u>zeotrope</u>	<u>R-1132a/32/1234yf</u> <u>(3.5/21.5/75.0)</u>	<u>A2L</u>	<u>4.1</u>	<u>18,000</u>	<u>66</u>				<u>610</u>	
<u>R-469A</u>	<u>zeotrope</u>	<u>R-744/R-32/R-125</u> <u>(35.0/32.5/32.5)</u>	<u>A1</u>	<u>8</u>	<u>53,000</u>	<u>13</u> <u>0</u>				<u>1,600</u>	
<u>R-470A</u>	<u>zeotrope</u>	<u>R-744/32/125/134a/1234ze(E)/</u> <u>227ea</u> <u>(10.0/17.0/19.0/7.0/44.0/3.0)</u>	<u>A1</u>	<u>17</u>	<u>77,000</u>	<u>27</u> <u>0</u>				<u>1,100</u>	
<u>R-470B</u>	<u>zeotrope</u>	<u>R-744/32/125/134a/1234ze(E)/</u> <u>227ea</u> <u>(10.0/11.5/11.5/3.0/57.0/7.0)</u>	<u>A1</u>	<u>16</u>	<u>72,000</u>	<u>26</u> <u>0</u>				<u>1,100</u>	
<u>R-471A</u>	<u>zeotrope</u>	<u>R-</u> <u>1234ze(E)/227ea/1336mzz(E)</u> <u>(78.7/4.3/17.0)</u>	<u>A1</u>	<u>9.7</u>	<u>31,000</u>	<u>16</u> <u>0</u>				<u>710</u>	
<u>R-472A</u>	<u>zeotrope</u>	<u>R-744/32/134a (69.0/12.0/19.0)</u>	<u>A1</u>	<u>4.5</u>	<u>35,000</u>	<u>72</u>				<u>2,700</u>	
R-500 ^{e,d}	azeotrope	R-12/152a (73.8/26.2)	A1	7.6 <u>7.4</u>	30,000 <u>29,000</u>	12 0				1,000	2-0-0 ^b
R-501 ^{d,c}	azeotrope	R-22/12 (75.0/25.0)	A1	13	54,000	21 0				1,000	—
R-502 ^{e,d}	azeotrope	R-22/115 (48.8/51.2)	A1	21	73,000	33 0				1,000	2-0-0 ^b
R-503 ^{e,d}	azeotrope	R-23/13 (40.1/59.9)	—	—	—	—				1,000	2-0-0 ^b
R-504 ^{d,c}	azeotrope	R-32/115 (48.2/51.8)	—	28	140,000	45 0				1,000	—
R-507A	azeotrope	R-125/143a (50.0/50.0)	A1	32	130,000	52 <u>0</u> <u>51</u> <u>0</u>				1,000	2-0-0 ^b
R-508A	azeotrope	R-23/116 (39.0/61.0)	A1	14	55,000	22 0				1,000	2-0-0 ^b

SUBMISSION FOR PERMANENT RULE

R-508B	azeotrope	R-23/116 (46.0/54.0)	A1	13	52,000	20 0				1,000	2-0-0 ^b
R-509A	azeotrope	R-22/218 (44.0/56.0)	A1	24	75,000	39 0 38 0				1,000	2-0-0 ^b
R-510A	azeotrope	R-E170/600a (88.0/12.0)	A3	0.87	7,300	14	<u>3.5</u>	<u>29,000</u>	<u>56.1</u>	1,000	—
R-511A	azeotrope	R-290/E170 (95.0/5.0)	A3	0.59	5,300	9.5	<u>2.4</u>	<u>21,000</u>	<u>38.0</u>	1,000	—
R-512A	azeotrope	R-134a/152a (5.0/95.0)	A2	1.9	11,000	31	<u>7.7</u>	<u>45,000</u>	<u>123.9</u>	1,000	—
R-513A	azeotrope	R-1234yf/134a (56.0/44.0)	A1	20	72,000	32 0				650	—
R-513B	azeotrope	R-1234yf/134a (58.5/41.5)	A1	21	74,000	33 0				640	—
R-514A	azeotrope	R-1336mzz(S)/1130(E) (74.7/25.3)	B1	0.86	2,400	14				320	—
R-515A	azeotrope	R-1234ze(E)/227ea (88.0/12.0)	A1	19	62,000 <u>63,000</u>	30 0				810	—
<u>R-515B</u>	<u>azeotrope</u>	<u>R-1234ze(E)/227ea (91.1/8.9)</u>	<u>A1</u>	<u>18</u>	<u>61,000</u>	<u>29</u> <u>0</u>				<u>810</u>	
R-516A	azeotrope	R-1234yf/134a/152a (77.5/8.5/14.0)	A2	7.0 <u>3.2</u>	27,000 <u>13,000</u>	11 <u>0</u> <u>52</u>	<u>13.1</u>	<u>50,000</u>	<u>210.1</u>	590	—

(continued)

**TABLE 1103.1—continued
REFRIGERANT CLASSIFICATION, AMOUNT AND OEL**

CHEMICAL REFRIGERANT	FORMULA	CHEMICAL NAME OF BLEND	REFRIGERANT SAFETY GROUP CLASSIFICATION	AMOUNT OF REFRIGERANT PER OCCUPIED SPACE						[F] DEGREE S OF HAZARD ^a	
				RCL		LFL		OEL ^d			
				Pounds per 1,000 cubic feet lb/Mcf	ppm	g/m ³	lb/Mcf	ppm	g/m ³		OEL ^e ppm
R-600	CH ₃ CH ₂ CH ₂ CH ₃	butane	A3	0.15	1,000	2.4	<u>3.0</u>	<u>20,000</u>	<u>48</u>	1,000	1-4-0
R-600a	CH(CH ₃) ₂ CH ₃	2-methylpropane (isobutane)	A3	0.59	4,000	9.6 <u>9.5</u>	<u>2.4</u>	<u>16,000</u>	<u>38</u>	1,000	2-4-0
R-601	CH ₃ CH ₂ CH ₂ CH ₂ CH ₃	pentane	A3	0.18	1,000	2.9	<u>2.2</u>	<u>12,000</u>	<u>35</u>	600	—
R-601a	(CH ₃) ₂ CHCH ₂ CH ₃	2-methylbutane (isopentane)	A3	0.18	1,000	2.9	<u>2.4</u>	<u>13,000</u>	<u>38</u>	600	—
R-610	CH ₃ CH ₂ OCH ₂ CH ₃	ethoxyethane (ethyl ether)	—	—	—	—	—	—	—	400	—
R-611	HCOOCH ₃	methyl formate	B2	—	—	—	—	—	—	100	—
R-718	H ₂ O	water	A1	—	—	—	—	—	—	—	0-0-0
R-744	CO ₂	carbon dioxide	A1	4.5	40,000	72				5,000	2-0-0 ^b

SUBMISSION FOR PERMANENT RULE

R-1130(E)	CHCl=CHCl	trans-1,2-dichloroethene	B1 B2	0.25	1,000	4	<u>16</u>	<u>65,000</u>	<u>258</u>	200	—
R-1132a	CF ₂ =CH ₂	1,1-difluoroethylene	A2	2.0	13,000	33	<u>8.1</u>	<u>50,000</u>	<u>131</u>	500	—
R-1150	CH ₂ =CH ₂	ethene (ethylene)	A3	—	—	—	<u>2.2</u>	<u>31,000</u>	<u>36</u>	200	1-4-2
R-1224yd(Z)	CF ₃ CF=CHCl	(Z)-1-chloro-2,3,3,3-tetrafluoroethylene	A1	23	60,000	36 0 37 0				1,000	—
R-1233zd(E)	CF ₃ CH=CHCl	trans-1-chloro-3,3,3-trifluoro-1-propene	A1	5.3	16,000	85				800	—
R-1234yf	CF ₃ CF=CH ₂	2,3,3,3-tetrafluoro-1-propene	A2 A2L	4.7 <u>4.5</u>	16,000	75	<u>18.0</u>	<u>62,000</u>	<u>289</u>	500	—
R-1234ze(E)	CF₃CH=CHF <u>CF₃CH=CFH</u>	trans-1,3,3,3-tetrafluoro-1-propene	A2 A2L	4.7	16,000	75 <u>76</u>	<u>18.8</u>	<u>65,000</u>	<u>303</u>	800	—
R-1270	CH ₃ CH=CH ₂	Propene (propylene)	A3	0.1	1,000	1.7				500	1-4-1
<u>R-1336mzz(E)</u>	<u>CF₃CH=CHCF₃</u>	<u>trans-1,1,1,4,4,4-hexafluoro-2-butene</u>	<u>A1</u>	<u>3.0</u>	<u>7,200</u>	<u>48</u>				<u>400</u>	
R-1336mzz(Z)	CF ₃ CHCHCF ₃	cis-1,1,1,4,4,4-hexafluoro-2-butene	A1	5.4 <u>5.2</u>	13,000	87 <u>84</u>				500	—

For SI: 1 pound = 0.454 kg, 1 cubic foot = 0.0283m³

- a. Degrees of hazard are for health, fire, and reactivity, respectively, in accordance with NFPA 704.
 - b. Reduction to 1-0-0 is allowed if analysis satisfactory to the code official shows that the maximum concentration for a rupture or full loss of refrigerant charge would not exceed the IDLH, considering both the refrigerant quantity and room volume.
 - e. ~~The ASHRAE Standard 34 flammability classification for this refrigerant is 2L, which is a subclass of Class 2.~~
 - ~~d.~~ c. Class I ozone depleting substance; prohibited for new installations.
 - e. ~~d.~~ Occupational Exposure Limit based on the OSHA PEL, ACGIH TLV-TWA, the TERA WEEL or consistent value on a time-weighted average (TWA) basis (unless noted C for ceiling) for an 8 hr/d and 40 hr/wk.
-

1104.3.1 Air conditioning for human comfort. ~~In other than industrial occupancies where the quantity in a single independent circuit does not exceed the amount in Table 1103.1, Group B1, B2 and B3 refrigerants shall not be used in high probability systems for air conditioning for human comfort. High-probability systems used for human comfort shall use Group A1 or A2L refrigerant.~~

Exceptions:

1. Equipment listed for and used in residential occupancies containing a maximum of 6.6 pounds (3 kg) of refrigerant.
2. Equipment listed for and used in commercial occupancies containing a maximum of 22 pounds (10 kg) of refrigerant.
3. Industrial occupancies.

1104.3.2 Nonindustrial occupancies Group A2, A3, B2 and B3 refrigerants. ~~Group A2 and B2 refrigerants shall not be used in high probability systems where the quantity of refrigerant in any independent refrigerant circuit exceeds the amount shown in Table 1104.3.2. Group A2 and B2 refrigerants shall not be used in high-probability systems. Group A3 and B3 refrigerants shall not be used except where approved.~~

ExceptionExceptions: ~~This section does not apply to laboratories where the floor area per occupant is not less than 100 square feet (9.3 m²).~~

1. Laboratories where the floor area per occupant is not less than 100 square feet (9.3 m²).
2. Listed self-contained systems having a maximum of 0.331 pounds (150 g) of Group A3 refrigerant.
3. Industrial occupancies.
4. Equipment listed for and used in residential occupancies containing a maximum of 6.6 pounds (3 kg) of Group A2 or B2 refrigerant.
5. Equipment listed for and used in commercial occupancies containing a maximum of 22 pounds (10 kg) of Group A2 or B2 refrigerant.

SUBMISSION FOR PERMANENT RULE

**TABLE 1104.3.2
MAXIMUM PERMISSIBLE QUANTITIES OF REFRIGERANTS**

TYPE OF REFRIGERATION SYSTEM	MAXIMUM POUNDS FOR VARIOUS OCCUPANCIES			
	Institutional	Public assembly	Residential	All other occupancies
Sealed absorption system				
— In exit access	0	0	3.3	3.3
— In adjacent outdoor locations	0	0	22	22
— In other than exit access	0	6.6	6.6	6.6
Unit systems				
— In other than exit access	0	0	6.6	6.6

For SI: 1 pound = 0.454 kg.

....

1106.3 Flammable Class 2 and 3 refrigerants. Where refrigerants of Groups A2, A3, B2 and B3 are used, the *machinery room* shall conform to the Class I, Division 2, *hazardous location* classification requirements of NFPA 70.

~~**Exception:** *Machinery rooms* for systems containing Group A2L refrigerants that are provided with ventilation in accordance with Section 1106.4.~~

~~**1106.4 Special requirements for Group A2L refrigerant machinery rooms.** *Machinery rooms* with systems containing Group A2L refrigerants that do not conform to the Class I, Division 2, *hazardous location* electrical requirements of NFPA 70, as permitted by the exception to Section 1106.3, shall comply with Sections 1106.4.1 through 1106.4.3.~~

~~**Exception:** *Machinery rooms* conforming to the Class I, Division 2, *hazardous location* classification requirements of NFPA 70 are not required to comply with Sections 1106.4.1 and 1106.4.2.~~

~~**1106.4 Group A2L and B2L refrigerant.** *Machinery rooms* for Group A2L and B2L refrigerant shall comply with Sections 1106.4.1 through Section 1106.4.3.~~

~~**[F] 1106.4.1 Ventilation system activation.** Ventilation shall be activated by the refrigerant detection system in the *machinery room*. Refrigerant detection systems shall be in accordance with Section 608.9 of the *International Fire Code* and all of the following:~~

- ~~1. The detectors shall activate at or below a refrigerant concentration of 25 percent of the LFL.~~
- ~~2. Upon activation, the detection system shall activate the emergency ventilation system required by Section 1106.4.2.~~
- ~~3. The detection, signaling and control circuits shall be supervised.~~

~~**1106.4.1 Elevated temperatures.** Open flame-producing devices or continuously operating hot surfaces over 1290°F (700°C) shall not be permanently installed in the room.~~

~~**1106.4.2 Emergency ventilation system.** An emergency ventilation system shall be provided at the minimum exhaust rate specified in ASHRAE 15 or Table 1106.4.2. Shutdown of the emergency ventilation system shall be by manual means.~~

~~**1106.4.2 Refrigerant detector.** In addition to the requirements of Section 1105.3, refrigerant detectors shall signal an alarm and activate the ventilation system in accordance with the response time specified in Table 1106.4.2.~~

**TABLE 1106.4.2
MINIMUM EXHAUST RATES**

REFRIGERANT	Q(m/sec)	Q(cfm)
R32	15.4	32,600
R143	13.6	28,700
R444A	6.46	13,700
R444B	10.6	22,400
R445A	7.83	16,600
R446A	23.9	50,700
R447A	23.8	50,400

SUBMISSION FOR PERMANENT RULE

R451A	7.04	15,000
R451B	7.05	15,000
R1234yf	7.80	16,600
R1234ze(E)	5.92	12,600

TABLE 1106.4.2 GROUP A2L and B2L DETECTOR ACTIVATION

Activation Level	Maximum Response Time (seconds)	ASHRAE 15 Ventilation Level	Alarm Reset	Alarm Type
<u>Less than or equal to the OEL in Table 1103.1</u>	<u>300</u>	<u>1</u>	<u>Automatic</u>	<u>Trouble</u>
<u>Less than or equal to the refrigerant concentration level in Table 1103.1</u>	<u>15</u>	<u>2</u>	<u>Manual</u>	<u>Emergency</u>

1106.4.3 Emergency ventilation system discharge. The emergency ventilation system point of discharge to the atmosphere shall be located outside of the structure at not less than 15 feet (4572 mm) above the adjoining grade level and not less than 20 feet (6096 mm) from any window, ~~ventilation opening or exit.~~

1106.4.3 Mechanical ventilation. The *machinery room* shall have a mechanical ventilation system complying with ASHRAE 15.

....

**TABLE 1107.4
REFRIGERANT PIPE**

PIPING MATERIAL	STANDARD
Aluminum tube	ASTM B210/ASTM B210M, ASTM B491/B491M
Brass (copper alloy) pipe	ASTM B43
Copper linesets	ASTM B280, ASTM B1003
Copper pipe	ASTM B42, ASTM B302
Copper tube ^a	ASTM B68, ASTM B75, ASTM B88, ASTM B280, ASTM B819
Steel pipe ^b	ASTM A53, ASTM A106, <u>ASTM A333</u>
Steel tube	ASTM A254, ASTM A334

a. Soft annealed copper tubing larger than 1³/₈ inch (35 mm) O.D. shall not be used for field-assembled refrigerant piping unless it is protected from mechanical damage.

b. ASTM A53, Type F steel pipe shall ~~not be used for refrigerant lines having an operating temperature less than 20°F (-29°C).~~ only be permitted for discharge lines in pressure relief systems.

....

**TABLE 1107.5
REFRIGERANT PIPE FITTINGS**

FITTING MATERIAL	STANDARD
Aluminum	ASTM B361
Brass (copper alloy)	ASME B16.15, ASME B16.24

SUBMISSION FOR PERMANENT RULE

Copper and Copper Alloy (Brass)	ASME B16.15, ASME B16.18, ASME B16.22, ASME B16.24, ASME B16.26, ASME B16.50
Steel	ASTM A105, ASTM A181, ASTM A193, ASTM A234, ASTM A420, ASTM A707

....

1107.7 Flexible connectors, expansion and vibration compensators. Flexible connectors and expansion and vibration control devices shall be *listed* and *labeled* for use in refrigerant systems and pressures for which the components are installed.

....

1109.2.2 Refrigerant pipe enclosure. Refrigerant piping shall be protected by locating it within the building elements or within protective enclosures.

Exception: Piping protection within the building elements or protective enclosure shall not be required in any of the following locations:

1. Where installed without ready access or located more than 7 feet 3 inches (2210 mm) above the finished floor.
2. Where located within 6 feet (1829 mm) of the refrigerant unit or *appliance*.
3. Where located in a *machinery room* complying with Section 1105.
4. Outside the building:
 - 4.1 Protected from damage from the weather, including, but not limited to, hail, ice, and snow loads and
 - 4.2 Protected from damage within the expected foot or traffic path or
 - 4.3 Outside, underground, installed not less than 8 inches (200 mm) below finished grade and protected against corrosion.

1109.2.3 Prohibited locations. Refrigerant piping shall not be installed in any of the following locations:

1. Exposed within a fire-resistance-rated exit access corridor.
2. ~~Exposed within~~ Within an interior exit stairway.
3. Within an interior exit ramp.
4. Within an exit passageway.
5. Within an elevator, dumbwaiter or other shaft containing a moving object.

....

1109.2.6 Exposed piping surface temperature. Exposed piping with ready access to nonauthorized personnel having surface temperatures greater than 120°F (49°C) or less than 5°F (-15°C) shall be protected from contact or shall have thermal insulation that limits the exposed insulation surface temperature to a range of 5°F (-15°C) to 120°F (49°C).

1109.2.7 Pipe identification. Refrigerant pipe located in areas other than the room or space where the refrigerating *equipment* is located shall be identified. The pipe identification shall be located at intervals not exceeding 20 feet (6096 mm) on the refrigerant piping or pipe insulation. The minimum height of lettering of the identification label shall be 1/2 inch (12.7 mm). The identification shall indicate the refrigerant designation and safety group classification of refrigerant used in the piping system. For Group A2L and B2L refrigerants, the identification shall also include the following statement: "WARNING – Risk of Fire. Flammable Refrigerant." For Group A2, A3, B2 and B3 refrigerants, the identification shall also include the following statement: "DANGER—Risk of Fire or Explosion. Flammable Refrigerant." For any Group B refrigerant, the identification shall also include the following statement: "DANGER—Toxic Refrigerant."

1109.3 Installation requirements for Group A2L, ~~A2, A3, or~~ B2L, B2, or B3 refrigerant. Piping systems using Group A2L, ~~A2, A3 or~~ B2L, B2, or B3 refrigerant shall comply with the requirements of Sections 1109.3.1 and 1109.3.2.

1109.3.1 Pipe protection. In addition to the requirements of Section 305.5, aluminum, copper and steel tube used for Group A2L, ~~A2, A3, and~~ B2L, B2, and B3 refrigerants and located in concealed locations where tubing is installed in studs, joists, rafters or similar member spaces, and located less than 1 1/2 inches (38 mm) from the nearest edge of the member, shall be continuously protected by shield plates. Protective steel shield plates having a minimum thickness of 0.0575 inch (1.46 mm) (No. 16 gage) shall cover the area of the tube plus the area extending not less than 2 inches (51 mm) beyond both sides of the tube.

SUBMISSION FOR PERMANENT RULE

1109.3.2 Shaft ventilation. Refrigerant pipe shafts with systems using Group A2L or B2L refrigerant shall be naturally or mechanically ventilated. Refrigerant pipe shafts with one or more systems using any Group A2, A3, B2, or B3 refrigerant shall be continuously mechanically ventilated and shall include a refrigerant detector. The shaft ventilation exhaust outlet shall comply with Section 501.3.1. Naturally ventilated shafts shall have a pipe, duct or conduit not less than 4 inches (102 mm) in diameter that connects to the lowest point of the shaft and extends to the outdoors. The pipe, duct or conduit shall be level or pitched downward to the outdoors. Mechanically ventilated shafts shall have a minimum airflow velocity in accordance with Table 1109.3.2. The mechanical ventilation shall be continuously operated or activated by a refrigerant detector. Systems utilizing a refrigerant detector shall activate the mechanical ventilation at a maximum refrigerant concentration of 25 percent of the lower flammable limit of the refrigerant. The detector, or a sampling tube that draws air to the detector, shall be located in an area where refrigerant from a leak will concentrate. The shaft shall not be required to be ventilated for double-wall refrigerant pipe where the interstitial space of the double-wall pipe is vented to the outdoors.

....

~~1109.4 Installation requirements for Group A2, A3, B2 or B3 refrigerant.~~ Piping systems using Group A2, A3, B2 or B3 refrigerant shall comply with the requirements of Sections 1109.4.1 and 1109.4.2.

~~1109.4.1 Piping material.~~ Piping material for Group A2, A3, B2 or B3 refrigerant located inside the building, except for *machinery rooms*, shall be copper pipe, brass pipe or steel pipe. Pipe joints located in areas other than the *machinery room* shall be welded. Self-contained *listed* and *labeled equipment* or *appliances* shall have piping material based on the listing requirements.

~~1109.4.2 Shaft ventilation.~~ Refrigerant pipe shafts with systems using Group A2, A3, B2 or B3 refrigerant shall be continuously mechanically ventilated. The shaft ventilation exhaust outlet shall comply with Section 501.3.1. Mechanically ventilated shafts shall have a minimum airflow velocity as specified in Table 1109.3.2. The shaft shall not be required to be ventilated for double wall refrigerant pipe where the interstitial space of the double wall pipe is vented to the outdoors.

~~1109.5~~**1109.4 Refrigerant pipe penetrations.** The annular space between the outside of a refrigerant pipe and the inside of a pipe sleeve or opening in a building envelope wall, floor or ceiling assembly penetrated by a refrigerant pipe shall be sealed in a manner with caulking material or foam sealant or closed with a gasketing system. The caulking material, foam sealant or gasketing system shall be designed for the conditions at the penetration location and shall be compatible with the pipe, sleeve and building materials in contact with the sealing materials. Refrigerant pipes penetrating fire-resistance-rated assemblies or membranes of fire-resistance-rated assemblies shall be sealed or closed in accordance with Section 714 of the *International Building Code*.

~~1109.6~~**1109.5 Stress and strain.** Refrigerant piping shall be installed so as to prevent strains and stresses that exceed the structural strength of the pipe. Where necessary, provisions shall be made to protect piping from damage resulting from vibration, expansion, contraction and structural settlement.

~~1109.7 Condensate control.~~ Refrigerating piping and fittings that, during normal operation, will reach a surface temperature below the dew point of the surrounding air, and are located in spaces or areas where condensation has the potential to cause a safety hazard to the building occupants, structure, electrical *equipment* or any other *equipment* or *appliances*, shall be insulated or protected in an *approved* manner to prevent damage from condensation.

~~1109.8~~**1109.6 Stop valves.** Stop valves shall be installed in specified locations in accordance with Sections ~~1109.8.1~~**1109.6.1** and ~~1109.8.2~~**1109.6.2**. Stop valves shall be supported in accordance with Section ~~1109.8.3~~**1109.6.3** and identified in accordance with Section ~~1109.8.4~~**1109.6.4**.

Exceptions:

1. Systems that have a refrigerant pumpout function capable of storing the entire refrigerant charge in a receiver or heat exchanger.
2. Systems that are equipped with provisions for pumping out the refrigerant using either portable or permanently installed refrigerant recovery *equipment*.
3. Self-contained *listed* and *labeled* systems.

~~1109.8.1~~**1109.6.1 Refrigerating systems containing more than 6.6 pounds (3.0 kg) of refrigerant.** Stop valves shall be installed in the following locations on refrigerating systems containing more than 6.6 pounds (3.0 kg) of refrigerant:

1. The suction inlet of each compressor, compressor unit or condensing unit.
2. The discharge outlet of each compressor, compressor unit or condensing unit.
3. The outlet of each liquid receiver.

SUBMISSION FOR PERMANENT RULE

~~1109.8.2~~1109.6.2 **Refrigerating systems containing more than 100 pounds (45 kg) of refrigerant.** In addition to stop valves required by Section ~~1109.8.1~~1109.6.1, systems containing more than 100 pounds (45 kg) of refrigerant shall have stop valves installed in the following locations:

1. Each inlet of each liquid receiver.
2. Each inlet and each outlet of each condenser where more than one condenser is used in parallel.

Exceptions:

1. Stop valves shall not be required at the inlet of a receiver in a condensing unit nor at the inlet of a receiver that is an integral part of the condenser.
2. Systems utilizing nonpositive displacement compressors.

~~1109.8.3~~1109.6.3 **Stop valve support.** Stop valves shall be supported to prevent detrimental stress and strain on the refrigerant piping system. The piping system shall not be utilized to support stop valves on copper tubing or aluminum tubing 1 inch (25.4 mm) outside diameter or larger.

~~1109.8.4~~1109.6.4 **Identification.** Stop valves shall be identified where their intended purpose is not obvious. Where valves are identified by a numbering or lettering system, legend(s) or key(s) for the valve identification shall be located in the room containing the indoor refrigeration *equipment*. The minimum height of lettering of the identification label shall be 1/2 inch (12.7 mm).

~~1109.9~~1109.7 **Pipe Supports.** Pipe supports shall be in accordance with Section 305.

....

1110.3 Test gases. The medium used for pressure testing the refrigerant system shall be one of the following inert gases: oxygen-free nitrogen, helium, ~~or~~ argon or premixed nonflammable oxygen-free nitrogen with a tracer gas of hydrogen or helium. For R-744 refrigerant systems, carbon dioxide shall be allowed as the test medium. For R-718 refrigerant systems, water shall be allowed as the test medium. ~~Oxygen, air, combustible gases and mixtures containing such gases shall not be used as a test medium. Systems erected on the premises with tubing not exceeding 5/8-inch (15.9 mm) outside diameter shall be allowed to use the refrigerant identified on the nameplate label or marking as the test medium.~~

1110.3.1 Test gases not permitted. Oxygen, air, refrigerants other than those identified in Section 1110.3, combustible gases and mixtures containing such gases shall not be used as the pressure test medium.

....

1110.5 Piping system ~~strength test pressure test and leak test.~~ Refrigerating system components and refrigerant piping shall be tested in accordance with ASME B31.5 or this section. Separate tests for isolated portions of the system are permitted provided that all required portions are tested at least once. Pressurize with test gas for a minimum of 10 minutes to not less than the lower of (a) the lowest design pressure for any system component, or (b) the lowest value of set pressure for any pressure relief devices in the system. The design pressures for determination of test pressure shall be the pressure identified on the label nameplate of the condensing unit, compressor, compressor unit, pressure vessel, or other system component with a nameplate. A passing test result shall have no rupture or structural failure of any system component or refrigerant piping. Refrigerant piping and tubing greater than 3/4 inch (19 mm) in diameter shall be tested in accordance with ASHRAE 15. The refrigerant piping system shall be tested as a whole or separate tests shall be conducted for the low pressure side and high pressure side of the piping system. The refrigerant piping system shall be tested in accordance with both of the following methods:

1. The system shall be pressurized for a period of not less than 60 minutes to not less than the lower of the design pressures or the setting of the pressure relief device(s). The design pressures for testing shall be the pressure *listed* on the label nameplate of the condensing unit, compressor, compressor unit, pressure vessel or other system component with a nameplate. Additional test gas shall not be added to the system after the start of the pressure test. The system shall not show loss of pressure on the test pressure measuring device during the pressure test. Where using refrigerant as a test medium in accordance with Section 1110.3, the test pressure shall be not less than the saturation dew point pressure at 77°F (25°C).
2. A vacuum of 500 microns shall be achieved. After achieving a vacuum, the system shall be isolated from the vacuum pump. The system pressure shall not rise above 1,500 microns for a period of not less than 10 minutes.

~~**1110.5.1 Joints and refrigerant containing parts in air ducts.** Joints and all refrigerant containing parts of a refrigerating system located in an air duct of an air conditioning system that conveys conditioned air to and from human occupied spaces shall be tested at a pressure of 150 percent of the higher of the design pressure or pressure relief device setting.~~

SUBMISSION FOR PERMANENT RULE

~~1110.5.2 Limited charge systems.~~ Limited charge systems with a pressure relief device, erected on the premises, shall be tested at a pressure not less than one and one-half times the pressure setting of the relief device. ~~Listed and labeled limited charge systems shall be tested at the equipment or appliance design pressure.~~

~~1110.6 Booster compressor.~~ Where a compressor protected by a pressure relief device is used as a booster to obtain an intermediate pressure, and such compressor discharges into the suction side of another compressor, the booster compressor shall be considered to be a part of the low pressure side of the system.

~~1110.7 Centrifugal/nonpositive displacement compressors.~~ Where testing systems using centrifugal or other nonpositive displacement compressors, the entire system shall be considered to be the low pressure side for test purposes.

~~1110.8~~**1110.6 Contractor or engineer declaration.** The installing contractor or *registered design professional* of record shall issue a certificate of test to the code official for all systems containing 55 pounds (25 kg) or more of refrigerant. The certificate shall give the test date, name of the refrigerant, test medium and the field test pressure applied to the high-pressure side and the low-pressure side of the system. The certification of test shall be signed by the installing contractor or *registered design professional* and shall be made part of the public record.

....

CHAPTER 15 REFERENCED STANDARDS

....

ASHRAE

ASHRAE
1791 Tullie Circle NE
Atlanta, GA 30329

15—~~2019~~2022

Safety Standard for Refrigeration Systems

1101.1.1, Table 1106.4.2, 1106.4.3, 1110.5

34—~~2019~~2022

Designation and Safety Classification of Refrigerants

1102.2.1, 1103.1, ~~Table 1103.1~~

....

ASTM

ASTM International
100 Barr Harbor Drive, P.O. Box C700
West Conshohocken, PA 19428

....

A333-18

Standard Specification for Seamless and Welded Steel Pipe for Low-Temperature Service and other Applications with required Notch Toughness

Table 1107.4

....

UL

UL LLC
333 Pfingsten Road
Northbrook, IL 60062-2096

SUBMISSION FOR PERMANENT RULE

....

UL/CSA 60335-2-40—20192022

**Household and Similar Electrical Appliances—Safety—Part 2-40: Particular Requirements for Electrical Heat Pumps,
Air-Conditioners and Dehumidifiers – 3rd Edition**


908.1, 916.1, 918.1, 918.2, Table 1101.2, 1101.2.1

UL/CSA 60335-2-89—172021

**Household and Similar Electrical Appliances—Safety—Part 2-89: Particular Requirements for Commercial
Refrigerating Appliances with an Incorporated or Remote Refrigerant Unit or Compressor**

Table 1101.2, 1101.2.1

SUBMISSION FOR PERMANENT RULE

1. Rule-Making Agency: NC Building Code Council			
2. Rule citation & name (name not required for repeal): 2024 NC Mechanical Code, Chapter 15 (230912 Item B-4)			
3. Action: <input type="checkbox"/> ADOPTION <input checked="" type="checkbox"/> AMENDMENT <input type="checkbox"/> REPEAL <input type="checkbox"/> READOPTION <input type="checkbox"/> REPEAL through READOPTION			
4. Rule exempt from RRC review? <input type="checkbox"/> Yes. Cite authority: <input checked="" type="checkbox"/> No	5. Rule automatically subject to legislative review? <input type="checkbox"/> Yes. Cite authority: <input checked="" type="checkbox"/> No		
6. Notice for Proposed Rule: <input checked="" type="checkbox"/> Notice Required Notice of Text published on: November 15, 2023 in NC Register Link to Agency notice: https://www.ncosfm.gov/codes/building-code-council-bcc/bcc-hearing-notice Hearing on: March 18, 2024 Adoption by Agency on: March 19, 2024 <input type="checkbox"/> Notice not required under G.S.: Adoption by Agency on:			
7. Rule establishes or increases a fee? (See G.S. 12-3.1) <input type="checkbox"/> Yes Agency submitted request for consultation on: Consultation not required. Cite authority: <input checked="" type="checkbox"/> No	8. Fiscal impact. Check all that apply. <input type="checkbox"/> This Rule was part of a combined analysis. <input type="checkbox"/> State funds affected <input type="checkbox"/> Local funds affected <input type="checkbox"/> Substantial economic impact (≥\$1,000,000) <input type="checkbox"/> Approved by OSBM <input checked="" type="checkbox"/> No fiscal note required		
9. REASON FOR ACTION			
9A. What prompted this action? Check all that apply: <table style="width: 100%; border: none;"> <tr> <td style="width: 50%; vertical-align: top;"> <input type="checkbox"/> Agency <input type="checkbox"/> Court order / cite: <input type="checkbox"/> Federal statute / cite: <input type="checkbox"/> Federal regulation / cite: </td> <td style="width: 50%; vertical-align: top;"> <input type="checkbox"/> Legislation enacted by the General Assembly Cite Session Law: <input checked="" type="checkbox"/> Petition for rule-making <input type="checkbox"/> Other: </td> </tr> </table>		<input type="checkbox"/> Agency <input type="checkbox"/> Court order / cite: <input type="checkbox"/> Federal statute / cite: <input type="checkbox"/> Federal regulation / cite:	<input type="checkbox"/> Legislation enacted by the General Assembly Cite Session Law: <input checked="" type="checkbox"/> Petition for rule-making <input type="checkbox"/> Other:
<input type="checkbox"/> Agency <input type="checkbox"/> Court order / cite: <input type="checkbox"/> Federal statute / cite: <input type="checkbox"/> Federal regulation / cite:	<input type="checkbox"/> Legislation enacted by the General Assembly Cite Session Law: <input checked="" type="checkbox"/> Petition for rule-making <input type="checkbox"/> Other:		
9B. Explain: These proposed amendments are based on the 2024 North Carolina Mechanical Code language but include updates based on approved 2024 ICC International Mechanical Code changes to these referenced standards – as related to A2L refrigerants. The delayed effective date of this Rule is January 1, 2025. The Statutory authority for Rule-making is G. S. 143-136; 143-138.			
10. Rulemaking Coordinator: David B. Rittlinger David B. Rittlinger Phone: (919)647-0008 E-Mail: david.rittlinger@ncdoi.gov Additional agency contact, if any: Phone: E-Mail:	11. Signature of Agency Head* or Rule-making Coordinator:  *If this function has been delegated (reassigned) pursuant to G.S. 143B-10(a), submit a copy of the delegation with this form. Typed Name: David B. Rittlinger Title: Chief Code Consultant		
RRC AND OAH USE ONLY			
Action taken: <input type="checkbox"/> RRC extended period of review: <input type="checkbox"/> RRC determined substantial changes: <input type="checkbox"/> Withdrawn by agency <input type="checkbox"/> Subject to Legislative Review <input type="checkbox"/> Other:			

SUBMISSION FOR PERMANENT RULE

ASHRAE	ASHRAE 1791 Tullie Circle, NE Atlanta, GA 30329	
15— 2019 <u>2022</u>	Safety Standard for Refrigeration Systems	1101.1, 1106.4.2
34— 2019 <u>2022</u>	Designation and Safety Classification of Refrigerants	1102.2.1, 1103..1, Table 1103.1
....		
UL	UL LLC 333 Pfingsten Road Northbrook, IL 60062-2096	
UL/CSA 60335-2-40- 2019 <u>2022</u>	Household And Similar Electrical Appliances - Safety — Part 2-40: Particular Requirements for Electrical Heat Pumps, Air- Conditioners and Dehumidifiers	908.1, 916.1, 918.1, 918.2, Table 1101.2
UL/CSA 60335-2-89- 17 <u>2021</u>	Household And Similar Electrical Appliances - Safety — Part 2-89: Particular Requirements for Commercial Refrigerating Appliances with an Incorporated or Remote Refrigerant Units or Compressor	Table 1101.2