

1 15A NCAC 02N .0201 is readopted as published in 35:4 NCR 426 as follows:

2
3 **SUBCHAPTER 02N – CRITERIA AND STANDARDS APPLICABLE TO UNDERGROUND STORAGE**
4 **TANKS**

5
6 **15A NCAC 02N .0201 APPLICABILITY**

7 The regulations governing "Applicability" set forth in 40 CFR 280.10 (Subpart A) are hereby incorporated by
8 ~~reference, reference excluding any subsequent amendments and editions,~~ except that:

- 9 (1) Underground underground storage tanks (UST) containing de minimis concentrations of regulated
10 substances are also subject to the requirements for permanent closure in Rules .0802 and .0803 of
11 this Subchapter; and
12 (2) UST systems that store fuel solely for use by emergency power generators installed on or after
13 November 1, 2007 shall also meet the requirements of Section .0900 of this Subchapter.

14
15 *History Note: Authority G.S. 143-215.3(a)(15); 143B-282(a)(2)(h); ~~150B-21.6;~~*
16 *Eff. January 1, 1991;*
17 *Amended Eff. June 1, 2017; November 1, ~~2007-2007;~~*
18 *Readopted Eff. January 1, 2021.*