1. Rule-Making Agency: NC Building Code Council		
2. Rule citation & name (name not required for repeal):		
2018 NC Building Code Section 3006.3 Hoistway opening pro	otection (210914 Item B-4)	
3. Action: ☐ ADOPTION ☑ AMENDMENT ☐ REPEAL ☐	READOPTION REPEAL through READOPTION	
4. Rule exempt from RRC review?	5. Rule automatically subject to legislative review?	
Yes. Cite authority:	☐ Yes. Cite authority:	
⊠ No	⊠ No	
6. Notice for Proposed Rule:		
⊠ Notice Required		
Notice of Text published on: November 1, 2021 Link to Agency notice: https://www.ncosfm.gov/codes/b	wilding-code-council-bcc/bcc-bearing-notices	
Hearing on: December 14, 2021	dinding-code-codificit-bee/ bee-nearing-notices	
Adoption by Agency on: March 15, 2022		
Notice not required under G.S.: Adoption by Agency on:		
Adoption by Agency on.		
7. Rule establishes or increases a fee? (See G.S. 12-3.1)	8. Fiscal impact. Check all that apply.	
□ Vaz	☐ This Rule was part of a combined analysis.	
☐ Yes Agency submitted request for consultation on:		
Consultation not required. Cite authority:	☐ State funds affected ☐ Local funds affected	
	☐ Substantial economic impact (≥\$1,000,000)	
⊠ No	Approved by OSBM	
	No fiscal note required	
	ON FOR ACTION	
9A. What prompted this action? Check all that apply:	Logiclation engeted by the Congrel Assembly	
	Legislation enacted by the General Assembly Cite Session Law:	
Federal statute / cite:	Petition for rule-making	
Federal regulation / cite:	Other:	
9B. Explain: The addition of the vision panel is required by the Elevator D	ivision of NC DOL to provide emergency responders the opportunity to	
	d draft control door and exposing the elevator shaft to possible smoke	
and hot gases.		
The delayed effective date of this Rule is January 1, 2023. The Statutory authority for Rule-making is G. S. 143-136; 14:	3-138.	
10. Rulemaking Coordinator: David B. Rittlinger David B. Rittlinger	11. Signature of Agency Head* or Rule-making Coordinator:	
Phone: (919)647-0008	700-11 do -	
E-Mail: david.rittlinger@ncdoi.gov	DBRAW	
Additional agency contact, if any:	*If this function has been delegated (reassigned) pursuant to	
Phone:	G.S. 143B-10(a), submit a copy of the delegation with this form.	
E-Mail:		
	Typed Name: David B. Rittlinger Title: Chief Code Consultant	
RRC AND OAH USE ONLY		
Action taken:		
RRC extended period of review:		
RRC determined substantial changes:		
Withdrawn by agency Subject to Legislative Review		
Subject to Legislative Review		

2018 NC Building Code 3006.3 Hoistway opening protection (210914 Item B-4)

3006.3 Hoistway opening protection. Where Section 3006.2 requires protection of the elevator hoistway door opening, the protection shall be provided by one of the following:

- 1. An enclosed elevator lobby shall be provided at each floor to separate the elevator hoistway *shaft enclosure* doors from each floor by fire partitions in accordance with Section 708. In addition, doors protecting openings in the elevator lobby enclosure walls shall comply with Section 716.5.3 as required for *corridor* walls. Penetrations of the enclosed elevator lobby by ducts and air transfer openings shall be protected as required for *corridors* in accordance with Section 717.5.4.1.
- 2. An enclosed elevator lobby shall be provided at each floor to separate the elevator hoistway *shaft enclosure* doors from each floor by smoke partitions in accordance with Section 710 where the building is equipped throughout with an *automatic sprinkler system* installed in accordance with Section 903.3.1.1 or 903.3.1.2. In addition, doors protecting openings in the *smoke partitions* shall comply with Sections 710.5.2.2, 710.5.2.3 and 716.5.9. Penetrations of the enclosed elevator lobby by ducts and air transfer openings shall be protected as required for *corridors* in accordance with Section 717.5.4.1.
- 3. Additional doors shall be provided at each elevator hoistway door opening in accordance with Section 3002.6. Such door shall comply with the smoke and draft control door assembly requirements in Section 716.5.3.1 when tested in accordance with UL 1784 without an artificial bottom seal and contain a vision panel as allowed by Table 716.5. The door shall not be installed in a way that affects the fire-resistance-rating or operation of the normal elevator shaft doors.
- 4. The elevator hoistway shall be pressurized in accordance with Section 909.21.

1. Rule-Making Agency: NC Building Code Council		
2. Rule citation & name (name not required for repeal): 2018 NC Fire Code Section 304.4.2.3 (210914 Item B-5)		
3. Action: ☐ ADOPTION ☐ AMENDMENT ☐ REPEAL ☐	READOPTION REPEAL through READOPTION	
4. Rule exempt from RRC review? ☐ Yes. Cite authority: ☒ No	5. Rule automatically subject to legislative review? ☐ Yes. Cite authority: ☒ No	
6. Notice Required Notice of Text published on: November 1, 2021 Link to Agency notice: https://www.ncosfm.gov/codes/building-code-council-bcc/bcc-hearing-notices Hearing on: December 14, 2021 Adoption by Agency on: March 15, 2022 Notice not required under G.S.: Adoption by Agency on:		
7. Rule establishes or increases a fee? (See G.S. 12-3.1)	8. Fiscal impact. Check all that apply.	
 ☐ Yes Agency submitted request for consultation on: Consultation not required. Cite authority: ☑ No 	 □ This Rule was part of a combined analysis. □ State funds affected □ Local funds affected □ Substantial economic impact (≥\$1,000,000) □ Approved by OSBM ⋈ No fiscal note required 	
9. REASON FOR ACTION 9A. What prompted this action? Check all that apply: Agency		
10. Rulemaking Coordinator: David B. Rittlinger David B. Rittlinger Phone: (919)647-0008 E-Mail: david.rittlinger@ncdoi.gov	11. Signature of Agency Head* or Rule-making Coordinator:	
Additional agency contact, if any: Phone: E-Mail:	*If this function has been delegated (reassigned) pursuant to G.S. 143B-10(a), submit a copy of the delegation with this form. Typed Name: David B. Rittlinger	
DDC 130	Title: Chief Code Consultant	
RRC AND OAH USE ONLY Action taken:		
RRC extended period of review: RRC determined substantial changes: Withdrawn by agency Subject to Legislative Review		

2018 NC Fire Code 304.4.2.3 (210914 Item B-5)

- **304.4.2.3.** Containers used for valet trash collection shall not exceed a capacity of 2.0 cubic feet (15 gallons, 0.06 cubic meters) and shall be provided with tight-fitting or self-closing lids. Containers and lids shall emply with either:
- 1. Containers and lids located in an area that is protected by fire sprinklers shall be constructed entirely of noncombustible materials or materials that meet a peak rate of heat release not exceeding 300 kW/m2 when tested in accordance with ASTM E 1354 at an incident heat flux of 50 kW/m2 in the horizontal orientation. Containers and lids shall be listed or bear the label of an approved agency that validates compliance with this requirement.; or
- 2. Containers and lids located in an area that is not protected by fire sprinklers shall be constructed entirely of noncombustible materials or materials that meet a peak rate of heat release not exceeding 150 kW/m2 when tested in accordance with ASTM E 1354 at an incident heat flux of 50 kW/m2 in the horizontal orientation. Containers and lids shall be listed or bear the label of an approved agency that validates compliance with this requirement

1. Rule-Making Agency: NC Building Code Council		
2. Rule citation & name (name not required for repeal): 2018 NC Building Code Section 3006.2 Hoistway opening protection required (210914 Item B-3)		
3. Action: ☐ ADOPTION ☐ AMENDMENT ☐ REPEAL ☐	READOPTION REPEAL through READOPTION	
4. Rule exempt from RRC review? ☐ Yes. Cite authority: ☒ No	5. Rule automatically subject to legislative review? ☐ Yes. Cite authority: ☒ No	
6. Notice for Proposed Rule:		
Notice Required Notice of Text published on: November 1, 2021 Link to Agency notice: https://www.ncosfm.gov/codes/building-code-council-bcc/bcc-hearing-notices Hearing on: December 14, 2021 Adoption by Agency on: March 15, 2022 Notice not required under G.S.: Adoption by Agency on:		
7. Rule establishes or increases a fee? (See G.S. 12-3.1)	8. Fiscal impact. Check all that apply.	
 Yes Agency submitted request for consultation on: Consultation not required. Cite authority: No 	 □ This Rule was part of a combined analysis. □ State funds affected □ Local funds affected □ Substantial economic impact (≥\$1,000,000) □ Approved by OSBM ⋈ No fiscal note required 	
9. REAS	ON FOR ACTION	
9A. What prompted this action? Check all that apply: Agency Court order / cite: Federal statute / cite: Federal regulation / cite: 9B. Explain: Addressing unfinished or unoccupied stories that would require possibility of smoke and hot gases from those vacant stories for	☐ Legislation enacted by the General Assembly Cite Session Law: ☐ Petition for rule-making ☐ Other: re such protection for occupied stories clarifies and prevents the rom entering the elevator shaft.	
The delayed effective date of this Rule is January 1, 2023. The Statutory authority for Rule-making is G. S. 143-136; 143-138.		
10. Rulemaking Coordinator: David B. Rittlinger	11. Signature of Agency Head* or Rule-making Coordinator:	
David B. Rittlinger Phone: (919)647-0008 E-Mail: david.rittlinger@ncdoi.gov	DBRAW	
Additional agency contact, if any: Phone: E-Mail:	*If this function has been delegated (reassigned) pursuant to G.S. 143B-10(a), submit a copy of the delegation with this form.	
	Typed Name: David B. Rittlinger Title: Chief Code Consultant	
RRC AND OAH USE ONLY Action taken:		
RRC extended period of review: RRC determined substantial changes: Withdrawn by agency Subject to Legislative Review Other		

2018 NC Building Code

3006.2 Hoistway opening protection required (210914 Item B-3)

3006.2 Hoistway opening protection required. Elevator hoistway door openings for occupied and unoccupied stories shall be protected in accordance with Section 3006.3 where an elevator hoistway connects more than three *stories*, is required to be enclosed within a *shaft enclosure* in accordance with Section 712.1.1 and any of the following conditions apply:

- 1. The building is not protected throughout with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or 903.3.1.2.
- 2. The building contains a Group I-1, Condition 2 occupancy.
- 3. The building contains a Group I-2 occupancy.
- 4. The building contains a Group I-3 occupancy.
- 5. The building is a high rise and the elevator hoistway is more than 75 feet (22 860 mm) in height. The height of the hoistway shall be measured from the *lowest floor* to the highest floor of the floors served by the hoistway.

Exceptions:

- 1. Protection of elevator hoistway door openings is not required where the elevator serves only *open parking garages* in accordance with Section 406.5.
- 2. Protection of elevator hoistway door openings is not required at the level(s) of [exit discharge] exit discharge, provided that the level(s) of [exit discharge] exit discharge is equipped with an automatic sprinkler system in accordance with Section 903.3.1.1.
- 3. Enclosed elevator lobbies and protection of elevator hoistway door openings are not required on levels where the elevator hoistway opens to the exterior.

	The state of the s	
1. Rule-Making Agency: NC Building Code Council		
2. Rule citation & name (name not required for repeal): 2018 NC Building Code Section 116 Unsafe Structures and Equipment (210914 Item B-2)		
3. Action:		
☐ ADOPTION ☒ AMENDMENT ☐ REPEAL ☐	READOPTION REPEAL through READOPTION	
4. Rule exempt from RRC review?	5. Rule automatically subject to legislative review? Yes. Cite authority:	
Yes. Cite authority:	No	
No Notice for Proposed Rule:	N 100	
To the same of the		
Notice Required Notice of Text published on: November 1, 2021		
Link to Agency notice: https://www.ncosfm.gov/codes/b	ouilding-code-council-bcc/bcc-hearing-notices	
Hearing on: December 14, 2021	specialistical (in the contraction of the contracti	
Adoption by Agency on: March 15, 2022		
Notice not required under G.S.:		
Adoption by Agency on:		
7. Rule establishes or increases a fee? (See G.S. 12-3.1)	8. Fiscal impact. Check all that apply.	
	☐ This Rule was part of a combined analysis.	
Yes	I mo rease was pare of a companied analysis	
Agency submitted request for consultation on: Consultation not required. Cite authority:	State funds affected	
Consultation not required. One authority.	Local funds affected	
⊠ No	Substantial economic impact (≥\$1,000,000)Approved by OSBM	
	No fiscal note required	
9 REAS	ON FOR ACTION	
9A. What prompted this action? Check all that apply:		
⊠ Agency	☐ Legislation enacted by the General Assembly	
Court order / cite:	Cite Session Law:	
Federal statute / cite:	Petition for rule-making	
Federal regulation / cite: 9B. Explain:	Other:	
Provides a direct means to protect the public from unsafe buil	dings. The NCFC also directs the fire official to notify the building	
official of an unsafe building, but the NCBC currently provide	es no direction on how to address securing an unsafe building.	
The delayed effective date of this Rule is January 1, 2023.		
The Statutory authority for Rule-making is G. S. 143-136; 143	3-138.	
	11. Signature of Agency Head* or Rule-making Coordinator:	
10. Rulemaking Coordinator: David B. Rittlinger David B. Rittlinger	11. Signature of Agency Head of Rule-making Coordinator.	
Phone: (919)647-0008	The state of the s	
E-Mail: david.rittlinger@ncdoi.gov	DB Roller	
A New January and of Street		
Additional agency contact, if any: Phone:	*If this function has been delegated (reassigned) pursuant to G.S. 143B-10(a), submit a copy of the delegation with this form.	
E-Mail:	G.S. 143D-10(a), submit a copy of the delegation with this form.	
Committee of the Commit	Typed Name: David B. Rittlinger	
	Title: Chief Code Consultant	
RRC AND OAH USE ONLY		
Action taken:		
RRC extended period of review:		
RRC determined substantial changes:		
☐ Withdrawn by agency ☐ Subject to Legislative Review		
Other:		

2018 NC Building Code Section 116 Unsafe Structures and Equipment (210914 Item B-2)

SECTION 116 UNSAFE STRUCURES AND EQUIPMENT

Deleted. See the North Carolina Administrative Code and Policies

116.1 General. Owners of [Unsafe] unsafe structures or equipment [must] shall comply with a code enforcement official's authority as described in [the] NC Administrative Code and Policies[z] Section 204.2.8[z] and G.S. 160D-1119.

116.2 Public access. The structure owner or his representative shall secure the unsafe structure by a method approved by the local building official to prevent public access. The approved method shall be in place within the time limit specified in writing by the building official in the notice of unsafe building.

1. Rule-Making Agency: NC Building Code Council		
2. Rule citation & name (name not required for repeal): 2018 NC Residential Code R404.4 Retaining Walls (210914 Item B-1)		
3. Action:	READOPTION REPEAL through READOPTION	
☐ ADOPTION ☐ AMENDMENT ☐ REPEAL ☐ 4. Rule exempt from RRC review?	5. Rule automatically subject to legislative review?	
Yes. Cite authority:	Yes. Cite authority:	
No Yes. Cite authority:	No	
6. Notice for Proposed Rule:	<u> </u>	
110 1		
Notice Required		
Notice of Text published on: November 1, 2021 Link to Agency notice: https://www.ncosfm.gov/codes/b	wilding and acupail hos/hos bearing notices	
Hearing on: December 14, 2021	ounding-code-council-bee/bee-nearing-notices	
Adoption by Agency on: March 15, 2022		
☐ Notice not required under G.S.:		
Adoption by Agency on:		
	1	
7. Rule establishes or increases a fee? (See G.S. 12-3.1)	8. Fiscal impact. Check all that apply.	
☐ Yes	☐ This Rule was part of a combined analysis.	
Agency submitted request for consultation on:	State funds affected	
Consultation not required. Cite authority:	Local funds affected	
⊠ No	☐ Substantial economic impact (≥\$1,000,000)	
⊠ No	Approved by OSBM	
	No fiscal note required	
Service and the service of the servi	ON FOR ACTION	
9A. What prompted this action? Check all that apply:		
⊠ Agency	Legislation enacted by the General Assembly	
Court order / cite:	Cite Session Law:	
☐ Federal statute / cite: ☐ Federal regulation / cite:	✓ Petition for rule-making✓ Other:	
9B. Explain:	□ ouci.	
	with the commercial code for retaining walls on a site not supporting a	
structure.		
The deleved effective data of this Pule is Innum; 1, 2025		
The delayed effective date of this Rule is January 1, 2025. The Statutory authority for Rule-making is G. S. 143-136; 14.	3-138.	
10. Rulemaking Coordinator: David B. Rittlinger David B. Rittlinger	11. Signature of Agency Head* or Rule-making Coordinator:	
Phone: (919)647-0008		
E-Mail: david.rittlinger@ncdoi.gov	DB BALLY-	
Additional agency contact, if any:	*If this function has been delegated (reassigned) pursuant to	
Phone:	G.S. 143B-10(a), submit a copy of the delegation with this form.	
E-Mail:	T IN D IID DW	
	Typed Name: David B. Rittlinger Title: Chief Code Consultant	
RRC AND OAH USE ONLY		
Action taken:		
DDC automoded posited of receivers		
RRC extended period of review: RRC determined substantial changes:		
Withdrawn by agency		
Subject to Legislative Review		
Other		

2018 NC Residential Code R404.4 Retaining Walls (210914 Item B-1)

R404.4 Retaining Walls. Retaining walls that meet the following shall be designed by a [registered design professional] registered design professional.

- 1. Any retaining [wall] walls systems on a residential site that cross over adjacent property lines regardless of vertical height, or
- 2. Retaining walls that support buildings and their accessory structures, undercutting footings [10'] 10 feet or less per R403.1.9 and Figure 403.1.9, or
- 3. Retaining Individual retaining walls supporting unbalanced backfill exceeding 4 feet (1219mm) 5 feet (1524 mm) of unbalanced backfill in height within a horizontal distance of 15 feet (4572 mm) or less, or
- 4. Retaining Multiple retaining walls systems providing a cumulative vertical relief of unbalanced backfill heights greater than 5 [Feet] feet (1524 mm) in height within a horizontal separation distance of 50 feet (15M) 15 feet (4572 mm) or less.

Retaining walls shall be designed for a safety factor of 1.5 against lateral sliding and overturning.