

REQUEST FOR TECHNICAL CHANGE

AGENCY: NC Building Code Council

RULE CITATION: 2014 NC Electrical Code, 680.21(C)

DEADLINE FOR RECEIPT: Tuesday, August 8, 2017

NOTE: This request when viewed on computer extends several pages. Please be sure you have reached the end of the document.

The Rules Review Commission staff has completed its review of this rule prior to the Commission's next meeting. The Commission has not yet reviewed this rule and therefore there has not been a determination as to whether the rule will be approved. You may call this office to inquire concerning the staff recommendation.

In reviewing these rules, the staff determined that the following technical changes need to be made:

In the Submission for Permanent Rule Form, please amend it to show that the Rule was published on February 15, 2017.

So that I am clear – will this amend the 2014 National Electrical Code as adopted by NC?

Correct. This will amend the current 2014 NCEC.

In (C)(1), remove the comma after “receptacle” and “motor”

Removed “comma” in both locations as suggested.

(1) Pool Pump Motor Replacement. Whenever a pool pump motor requires replacing and the existing branch circuit or receptacle providing power to the pump motor does not provide ground-fault circuit-interrupter protection for personnel as required by 680.21(C), the branch circuit or receptacle shall be updated to provide ground-fault circuit-interrupter protection for personnel.

Please retype the rule accordingly and resubmit it to our office at 1711 New Hope Church Road, Raleigh, North Carolina 27609.

**Barry Gupton, PE
Chief Code Consultant**

Amanda J. Reeder
Commission Counsel
Date submitted to agency: July 25, 2017