

REQUEST FOR TECHNICAL CHANGE

AGENCY: NC Building Code Council

RULE CITATION: All Codes and Amendments Submitted

DEADLINE FOR RECEIPT: Wednesday, August 9, 2017

NOTE: This request when viewed on computer extends several pages. Please be sure you have reached the end of the document.

The Rules Review Commission staff has completed its review of this rule prior to the Commission's next meeting. The Commission has not yet reviewed this rule and therefore there has not been a determination as to whether the rule will be approved. You may call this office to inquire concerning the staff recommendation.

In reviewing these rules, the staff determined that the following technical changes need to be made:

Please confirm compliance with G.S. 143-136(c) and (d) where applicable.

Wherever terms are italicized in text of the Rule, please confirm that means it is a term defined elsewhere within the Code.

On all Submission for Permanent Rule forms, the date the rules were published was February 15, 2017. Please update this on Box 6.

For the adoptions to update the Codes to 2015 International Code editions, this isn't a petition for rulemaking, is it? Instead, isn't it based upon G.S. 143-138(d)? If so, please change the answer to Box 9B of the Form.

Wherever you are deleting parts of a list, please confirm that when you publish, the remaining items will be renumbered. If they will not, is that because you need to keep cross-references intact?

Please retype the rule accordingly and resubmit it to our office at 1711 New Hope Church Road, Raleigh, North Carolina 27609.

Amanda J. Reeder
Commission Counsel
Date submitted to agency: July 27, 2016

REQUEST FOR TECHNICAL CHANGE

AGENCY: NC Building Code Council

RULE CITATION: 2014 NC Electrical Code, 680.21(C)

DEADLINE FOR RECEIPT: Tuesday, August 8, 2017

NOTE: This request when viewed on computer extends several pages. Please be sure you have reached the end of the document.

The Rules Review Commission staff has completed its review of this rule prior to the Commission's next meeting. The Commission has not yet reviewed this rule and therefore there has not been a determination as to whether the rule will be approved. You may call this office to inquire concerning the staff recommendation.

In reviewing these rules, the staff determined that the following technical changes need to be made:

In the Submission for Permanent Rule Form, please amend it to show that the Rule was published on February 15, 2017.

So that I am clear – will this amend the 2014 National Electrical Code as adopted by NC?

In (C)(1), remove the comma after “receptacle” and “motor”

Please retype the rule accordingly and resubmit it to our office at 1711 New Hope Church Road, Raleigh, North Carolina 27609.

Amanda J. Reeder
Commission Counsel
Date submitted to agency: July 25, 2017

2014 NC Electrical Code
680.21(C) Pool Pump Motor Replacement. (161213 Item B-5)

680.21 Motors

(C) GFCI Protection. Outlets supplying pool pump motors connected to single-phase, 120-volt through 240-volt branch circuits, whether by receptacle or by direct connection, shall be provided with ground-fault circuit-interrupter protection for personnel.

(1) Pool Pump Motor Replacement. Whenever a pool pump motor requires replacing and the existing branch circuit or receptacle, providing power to the pump motor, does not provide ground-fault circuit-interrupter protection for personnel as required by 680.21(C), the branch circuit or receptacle shall be updated to provide ground-fault circuit-interrupter protection for personnel.

The delayed effective date of this Rule is January 1, 2018.
The Statutory authority for Rule-making is G. S. 143-136; 143-138.